

PACIFIC POWER & LIGHT COMPANY
GENERAL RULES AND REGULATIONS
POINT OF DELIVERY

OREGON
RULE 5

Point of Delivery

The "point of delivery," unless otherwise specified by Company, is that location on the Consumer's building or structure where Company's circuit and Consumer's system are interconnected. Any additional service supplied to the same Consumer at other points of delivery or at a different voltage or phase classification shall be separately metered and billed.

Company will supply the exterior connection commonly known as "service connection" between Company's transformers or lines and the point of delivery. Consumer shall provide a stationary and structurally sound support for the attachment of the service connection on the consumer's premises in accordance with Company's published "Electric Service Requirements." If more than one service is required for delivery of electric power and energy to a Consumer, then (a) each service connection shall be separately metered and billed, or (b) Company may establish the "point of delivery" on its transformer platform or other structure and install one set of metering equipment, in which event all service wires and other facilities beyond the point of delivery shall be installed and owned by Consumer; provided, however, that when the metering equipment is separated from Consumer's premises by a street or railroad, Company will furnish, own and maintain the necessary overhead service wire over such street or railroad.

Should Consumer require delivery through more than one transformer installation, or require service from Company at more than one voltage or phase, each service connection of each voltage and phase will be separately metered and billed.

| | | |
|------------|--------------------------------------------------------|-----------------------------------------------------------------|
| Issued: | January 16, 2002 | P.U.C. OR No. 35 |
| Effective: | With service rendered on and after January 18, 2002 | First Revision of Sheet No. G Canceling Original Sheet No. G |

Issued By
D. Douglas Larson, Vice President, Regulation