

**Rule 3  
GENERAL RULES AND REGULATIONS – DESCRIPTION OF SERVICE**

---

Electric service furnished under this tariff will be alternating current, 60 hertz, single or three-phase, at one of the nominal standard voltages given below. This tariff contains specific charges and billing adjustments for standard primary voltage metering and delivery.

A. SECONDARY VOLTAGE:

1. Overhead Service

Single-phase, 120 volts, 2-wire, grounded  
Single-phase, 120/240 volts, 3-wire, grounded

Three-phase, 120/208 volts, 4-wire, grounded  
Three-phase, 120/240 volts, 4-wire, grounded  
Three-phase, 277/480 volts, 4-wire, grounded

Under certain conditions, at the option of Company, ungrounded three-phase 480 volt 3-wire service will be provided.

2. Underground Service

Single-phase, 120 volts, 2-wire, grounded  
Single-phase, 120/240 volts, 3-wire, grounded

Three-phase, 120/208 volts, 4-wire, grounded  
Three-phase, 277/480 volts, 4-wire, grounded

Under certain conditions, at the option of Company, grounded three-phase 120/240 volt 4-wire service will be provided.

3. Secondary delivery limitations: Company, at its option, may limit the maximum or minimum load served at any of the above secondary voltages through a single point of delivery to a size commensurate with the capacities of transformers of that voltage designated as a Company Standard.

B. PRIMARY VOLTAGE:

1. Standard Primary Voltage is three-phase, 7,200/12,470 and 12,000/20,800 volts 4-wire grounded.

2. Other than standard primary voltages is use by Company include 2,400/4,160 volt wye, 7,200 volt delta, and 19,800/34,500 volt wye.

3. Delivery at primary voltage will be at the option of Company, subject to any special conditions and restrictions that Company may determine to be necessary and only after the customer has signed a written contract.