

Rule 5
GENERAL RULES AND REGULATIONS – POINT OF DELIVERY

The "point of delivery," unless otherwise specified by Company, is that location on the customer's building or structure where Company's circuit and the customer's system are interconnected. The exact location of said Point of Delivery shall be at Company's discretion.

Company will supply the exterior connection commonly known as "service connection" between Company's transformers or lines and the Point of Delivery. The customer shall provide a structurally sound support for the attachment of the service connection on the customer premises with the clearances required for safety. The location and height of the attachment point shall be at Company's discretion. If more than one service is required for delivery of electric power and energy to a customer, then (a) each service connection shall be separately metered and billed, or (b) Company may establish the "Point of Delivery" on its transformer platform or other structure and install one set of metering equipment, in which event all service wires and other facilities beyond the point of delivery shall be installed and owned by the customer; provided, however, that when the metering equipment is separated from the customer's premises by a street or railroad, Company will furnish, own and maintain the necessary overhead service wire over such street or railroad.

Should the customer require delivery from Company through more than one Point of Delivery, or more than one voltage or phase classification at the same premises, the customer shall pay the cost of such facilities necessary to provide the additional service.

Issued: May 13, 2011
Advice No. 11-01

Effective: June 13, 2011

Issued By Pacific Power & Light Company

By: Andrea Kelly Andrea L. Kelly

Title: Vice President, Regulation