

Incentives for motors

Equipment Type	Size Category	Sub-Category	Minimum Efficiency Requirement	Customer Incentive
Variable Frequency Drives (HVAC fans and pumps)	≤ 100 horsepower	HVAC fans and pumps	See note 2	\$65/horsepower
Green Motor Rewinds	≥ 15 and ≤ 5,000 hp	--	Must meet GMPG standards	\$1/horsepower (See note 3)

Notes for motor incentives:

1. Equipment that meets or exceeds the efficiency requirements listed for the equipment category in the above table may qualify for the listed incentive.
2. Throttling or bypass devices, such as inlet vanes, bypass dampers, three-way valves or throttling valves must be removed or permanently disabled to qualify for HVAC fan or pump VFD incentives. VFDs required by or used to comply with the applicable version of the energy code are not eligible for incentives. Savings will only be realized for installations where a variable load is present.
3. Green motor rewind motors that are installed or placed in inventory may qualify for an incentive. For green motor rewinds, the participating electric motor service center is paid \$2/horsepower for eligible green motor rewinds. A minimum of \$1/horsepower is paid by the service center to the customer as a credit on the motor rewind invoice. The balance is retained by the service center.

GMPG = Green Motors Practices Group
 HVAC = Heating, Ventilating and Air Conditioning
 VFD = Variable Frequency Drive