

Distribution System Planning Public Workshop #9 June 24, 2022



Workshop #9 Information

Teams Meeting Information

- Microsoft Teams meeting
Join on your computer or mobile app
[Click here to join the meeting](#)

Or call in (audio only)

[+1 563-275-5003,,418028485#](#) United States, Davenport

Phone Conference ID: 418 028 485#

Please add the following to the Teams Chat when you log on to the meeting:

- Your Name
- Your Organization and Title/Role

- Please use **Microsoft Edge** or **Google Chrome** with Teams for best experience
- Please **place your phone on “Mute”** when not speaking
- If you call in using your phone in addition to joining via the online link, please make sure to **mute your computer audio**
- Please **do not use the “Hold”** function on your phone

- Please use the chat function in TEAMS to provide any questions or comments during this presentation. We will do our best to address those as they come up, if we are unable to get to them, we will follow-up directly or at an upcoming workshop.



Today's Agenda

1. Introductions and Review Agenda (10 minutes)
2. Review Pacific Power OR Service Territory (10 minutes)
3. Review Distribution Planning Process (60 minutes)
 - Study Cycle (5 Year Cycle)
 - Review Grid Needs Summary from latest cycle of DSP Studies
 - Review DSP Study Process – Highlighting Prioritization Steps
 - Review Current Year Distribution Investments (Results of last year's prioritization)

Break (10 minutes)

4. Pilot/Transitional Study Areas and Grid Needs (45 minutes)
 - Introduction to Pilot Areas and focus areas
 - Grid Need - Klamath
 - Review potential solutions (Traditional and Non-wires)
 - Outline next steps
5. Update on Community Engagement (20 minutes)
 - CIG Update
 - Local Engagement
6. Review DSP Part 2 Schedule and Upcoming Topics (10 minutes)



2) Pacific Power Service Territory and DSP



Pacific Power's Oregon Service Territory




Overview of Pacific Power – Oregon

- 502 distribution circuits
- 191 distribution substations

| Office | NORTH REGION | | | CENTRAL REGION | | | SOUTH REGION | |
|------------------------------|--|---|---|---|--|---|--|---|
| | Portland | Walla Walla | Yakima | Bend | Albany | Roseburg | Klamath Falls | Medford |
| Responsible Operating Areas | Clatsop (Astoria) Portland Hood River | Walla Walla Hermiston Pendleton Enterprise | Sunnyside Yakima | Madras Hood River Bend/Redmond Prineville | Albany Corvallis Dallas/Independence Cottage Grove Stayton Lebanon Lincoln City Junction City | Coos Bay Roseburg | Alturas Lakeview Mt Shasta Klamath Falls Yreka | Crescent City Medford Grants Pass |
| Distribution Profile | 95 Circuits 1,200 Line Miles 107,000 Customers | 42 Circuits 2,500 Line Miles 54,000 Customers | 106 Circuits 3,300 Line Miles 108,000 Customers | 65 Circuits 2,800 Line Miles 77,000 customers | 86 Circuits 3,700 Line Miles 137,000 Customers | 66 Circuits 2,300 Line Miles 70,000 Customers | 110 Circuits 5,000 Line Miles 75,000 Customers | 138 Circuits 5,700 Line Miles 156,000 Customers |
| District Specific Attributes | Portland UG Networks DA Pilot Project FHCA | | FHCA | High Growth Rate/New Connections FHCA | DA Pilot Project | FHCA | Multiple Code Requirements FHCA & HFTD Footprint Energy Storage Pilot | Large FHCA Footprint DA Pilot Project |

Pacific Power's Oregon Service Territory

- Dispersed and Varied Geography: Territory spans from Washington to California and the coast to Idaho, broken into eight distinct planning districts
- Diverse Circuit Loading/Composition:
 - Densest circuit in Portland with 638 customers per line mile
 - Least dense in Hermiston with one customer per line mile
 - Oregon average is 28 customers per line mile
- Diverse Environmental Conditions: Distribution in eight of nine Oregon climate zones
- Various Touchpoints: Interconnections with 16 other electrical power companies, including CAISO and Bonneville Power



3) Distribution System Planning Process (Highlight on Prioritization)




As-is DSP Studies – Cycle vs Ad-Hoc Studies

Distribution Planning Studies

- All distribution system planning studies are scheduled to be completed on a 5-year cycle.
- Study schedules are evaluated each year and studies may be shifted to occur sooner or later depending on a number of factors (high load growth activity, large load additions, etc.).
- Currently 99 planning studies on 5-year cycle in Pacific Power service territory.
- Generally, spend 2-3 months completing study analysis, review and prioritize results with Manager.

Ad-hoc Studies (Generation Interconnect or System Impact Study)

- Typically driven by load, generation interconnection service or transmission service requests
- Study is generally focused on a limited area, and the immediate effects of the request on reliability and load service
- Generally shorter timeframes to meet customer needs (~ 3-4 weeks for initial study).
- Customer shares in solution costs and influences what solutions to implement.





Distribution System Planning Grid Needs Context

Reviewed the latest Distribution System Planning Studies for all study areas in Oregon (excludes customer-driven or ad-hoc studies):

- Categorized the grid needs that were identified in the studies (see results below)
- Captured rough cost estimates for wires solutions and added that breakdown – 117 total Grid Needs Identified:
 - 32% between \$0 and \$5K,
 - 54% between \$5K and \$200K,
 - 14% more than \$200K

Findings:

- Grid needs found in 22% of circuits
- Overcapacity is the most common grid need (61% of found needs)
- 86% of found grid needs cost less than \$200K
- Of those needs, not all will be suitable for NWS



As-Is Distribution System Planning Process - Study Initiation Through Approval


Current process includes **Four** high-level Steps...

1) Start Study (Scheduled or Ad-hoc)

5 Yr. Study Cycle
(as scheduled)

Ad-Hoc Study
(Different Process)

2) Complete Study



3) Field Engineering Manager Review/Prioritization:

- A. Reviews All Scheduled Study Reports (~ 20/year)
- B. Ranks each Solution in priority order for each Investment Reason Category


4) Investment Delivery Prioritization and Approval:

- A. Each Investment Reason has a budget established for the year based on capital planning.
- B. Field Engineering Manager & Inv Delivery Director review prioritized list of solutions & approve in priority order until budgeted funds are exhausted.

As-Is Distribution System Planning Process

- Study Initiation Through Approval


The same **Four** steps with some detail...



As-Is Distribution System Planning Process

- Study Initiation Through Approval

The same **Four** steps indicating where **Prioritization** occurs...



As-Is Distribution System Planning Study Schedule

1) Start Study
(Scheduled or Ad-hoc)


5 Yr. Study Cycle
(as scheduled)

| Study Schedule | | | | | |
|----------------------|------------------------|----------------------|---------------------|----------------------|-------------------------|
| CY 2019 – 20 studies | | CY 2020 – 20 studies | | CY 2021 – 20 studies | |
| Office | Study Name | Office | Study Name | Office | Study Name |
| Albany | Harrisburg | Albany | Lebanon | Albany | Cottage Grove |
| Albany | Brownsville | Albany | Sweet Home | Albany | Oregon State University |
| Bend | Deschutes | Bend | Prineville | Albany | Stayton |
| Bend | Culver | Bend | Powell Butte | Bend | Bend |
| Klamath Falls | Alturas | Klamath Falls | Sacramento Canyon | Klamath Falls | Butte Valley |
| Klamath Falls | Agency Lake | Klamath Falls | Sprague River | Klamath Falls | Klamath Urban |
| Klamath Falls | Lower Klamath River | Klamath Falls | Yreka | Klamath Falls | Tulelake |
| Medford | Ashland & Talent | Medford | Glendale | Medford | Merlin |
| Medford | Gasquet-Patricks Creek | Medford | Grants Pass Urban | Medford | Upper Rogue |
| Medford | Klamath | Medford | Medford Urban North | Medford | Tolo-Gold Hill |
| Medford | Smith River | Medford | Ruch Area | Portland | Lincoln Network |
| Portland | Sherman County | Portland | Albina Network | Portland | Warrenton |
| Roseburg | North Umpqua | Portland | Lincoln Non-network | Portland | Astoria |
| Roseburg | North Spit | Portland | Hood River | Portland | Seaside |
| Roseburg | Coquille-Bandon | Roseburg | Myrtle Point | Roseburg | Roseburg Urban |
| Walla Walla | Touchet | Roseburg | Sutherlin-Oakland | Walla Walla | Pilot Rock |
| Walla Walla | Umapine | Walla Walla | Athena-Weston | Walla Walla | Pomeroy |
| Walla Walla | Hermiston-Umatilla | Walla Walla | Dodd Road | Walla Walla | Walla Walla |
| Yakima | Selah-Wenas | Walla Walla | Dayton-Waitsburg | Walla Walla | Pendleton |
| Yakima | Wapato-White Swan | Yakima | Yakima Urban | Yakima | Toppenish-Punkin Center |

As-Is “Complete Study” Process

2) Complete Study

5 Yr. Study Cycle
(as scheduled)



Distribution System Studies are conducted by Field Engineers who are intimately familiar with the area and equipment.
 Field Engineers support all day-to-day operations of the distribution systems and are the subject matter experts for their areas.
They are afforded latitude to utilize professional judgement in the execution of the studies and in the prioritization of grid needs and recommended solutions.


Guidance Provided by:
1E.3.1—Distribution System Planning Study Guide

Excerpt from Section 8.1 – Solution Optimization:
 “ To operate the distribution system in the most cost-effective manner possible, alternative solutions to problems must be considered and studied. Many problems may be solved by several different solutions or a combination of solutions. The easiest or most direct solution to a problem may not be the best or most economical one or yield the best utilization of the system.
Be creative; sometimes “off the wall” ideas lead to very cost-effective and innovative solutions. The solution chosen for the plan should factor in engineering, operating, and economic aspects.”

As-Is Distribution System Planning Process - Field Engineer Study Process

Start Study
(Scheduled or Ad-hoc)

2) Complete Study




The Prioritization process for distribution investments for Field Engineers occurs in three stages in the As-Is DSP process.



Prioritization: Grid Needs

The DSP Guide identifies potential operating issues/Grid Needs in the following rough **priority** order:



Prioritization: Grid Needs

Stage 1

Field Engineer identifies and prioritizes grid needs for each circuit .

Primary Steps: :

- Field Engineer identifies the grid need and determines the corrective action required to address the issue.
- Since grid needs (and corresponding solutions) can vary widely in scope, severity, and impact the Field Engineer is provided latitude to exercise professional judgement in the identification and prioritization of the grid need.

During assessment of the grid needs and potential solutions, the Field Engineer would consider the risks of not doing the project. Specifically, the Field Engineer would examine the grid need and potential solution(s) in terms of:

- Safety and protection of life and property
- Risk (Customer impact, type of issue, severity of issue)
- Preservation of company facilities
- Continuity of service
- Power Quality

2) Complete Study

Assess Model Results & Identify Potential Grid Needs

Tasks Required:

- ✓ Run CYME Model based on load forecast
- ✓ Identify and analyze grid need and timeline due to issue (For Example)
- ✓ Undervoltage
- ✓ Overvoltage
- ✓ Thermal overload

Apply initial solution to model and Re-analyze
Iterate until solutions have addressed issues

2) Complete Study

Identify and Determine Potential Solutions

Tasks Required:

- ✓ Identify and determine solution to resolve issue For example:
- ✓ Load transfer
- ✓ Phase balancing, Capacitor bank
- ✓ Etc.

Finalize proposed solution(s) to develop a project list (includes high-level scope of work, budget, and timeline)

Prioritization: Solution Identification and Analysis

Stage 2

Field Engineer analyzes potential solutions, in consultation with Manager/SMEs "DSM Guide"

Once primary solution is identified to address the grid need, the Field Engineer will:

- Identify and model the solution and any alternative solutions in CYME
- Confirm recommended solution addresses the technical needs for the remainder of the study cycle.

Alternatives are provided along with the recommended solution in the Study Summary Report for consideration.

The common solutions are further explained in text provide further guidance. The common solution titles are listed to the right for ease of reference.

Prioritization: Solution Identification (Cont.)

Titles of Common Solutions from DSP Guide Book

- 1A Build New Substation
- 2A Replace or Add Substation Transformer
- 2B Add Substation Cooling Equipment
- 2C Parallel Substation Transformers
- 3A Replace Overhead Substation Equipment
- 3B Increase Getaway Capacity
- 3C Add Parallel Circuit Getaway
- 4A New Feeder
- 4B Transfer Load
- 5A Reconductor
- 5B Reconfigure System
- 5C Add Underground Cable
- 5D Remove an Environmental Hazard
- 6A Replace Equipment
- 6B Add Distribution Automation Equipment
- 7A Replace Regulator
- 7B Limit Regulator Operating Range
- 7C Add Secondary Regulators
- 7D Change Regulator Control Settings
- 7E Add Line Regulator
- 7F Relocate Line Regulator
- 8A Install Line Capacitors
- 8B Install Capacitor Switches and Controls
- 9A Replace Step-up or Step-down Transformers
- 9B Change Utilization Transformers Taps
- 9C Voltage Conversion
- 10A Add Protective Device
- 10B Replace Protective Equipment
- 10C Relocate Protective Equipment
- 11A Demand Side Management

2) Complete Study

Develop Study Summary & Proposal for Investment Delivery

Tasks Required:
Develop proposal for each project listed which includes:

- ✓ Description of work to be performed
- ✓ Purpose and Necessity
- ✓ Risk Assessment
- ✓ Alternatives Considered
- ✓ Preliminary Cost Estimate
- ✓ Investment Reason

Proposals go to Investment Delivery to get incorporated into capital plan

Prioritization: Study Summary Report
Document outlines recommended + alternative solutions – Assigns Investment Reason for Budget Prioritization

Stage 3

Prioritization: Study Summary Report

The Field Engineer creates the DSP Report and Construction Plan for Approval including:

- Report Preface
- Study Summary: grid needs, costs/benefits and risks for recommended and alternative solutions
- Load Forecast for each substation and circuit in the study
- Purpose and Necessity (Investment Reason) for each proposed solution (more on this below)
- Map(s) showing study area and proposed budget items
- Construction Plan and Approval

*The recommended solution includes a level of **prioritization** (that is - the recommended solution is prioritized above the alternative solutions), but there is not further prioritization among a variety of potential solutions until the reports are compiled and prioritized in the next step.*

Each solution assigned to an **“Investment Reason”** - categories that “define the business reasons driving construction of a given capital project... not simply an explanation of the type of work to be performed”. The Investment Reason ties directly to budgets that outline work activities.

Prioritization – Field Engineering Manager

3) Field Engineering Manager Review/Prioritization:

- A. Reviews All Scheduled Study Reports (~ 20/year)



- B. Ranks each Solution in priority order for each Investment Reason Category

Prioritization: Field Engineering Manager (One Person)

- Reviews all Study Reports & recommended solutions during study and prior to prioritization.
- Ranks each proposed solution from all of the studies in rank order (priority) based on:
 - Potential risk and impact
 - Timing (when solution needed/how long will it take to implement)
 - Any relationships to other solutions
 - Consultation with Field Engineer/Ops Managers

Ranked List Reinforcements



Ranked List Feeder Improvements



Ranked List Substation Improvements



Field Engineering Manager Review and Approval: All DSP Reports and Construction Plans are reviewed and approved by the Field Engineering Manager (a single person) and the specific solutions are captured for prioritization.

The solutions' Purpose and Necessity/Investment Reason dictates the type of solution that is needed. The Investment Reasons are themselves a form of prioritization in the process.

Field Engineering Manager prioritization: compiles a list of all identified solutions and prioritizes the list by the Investment Reason. **This is the critical prioritization step** as the Manager (in consultation with the Field Engineers) force ranks the proposed solutions into **priority** order based on:

- Type of Issue and Severity
- Risk associated with issue
- Alternatives available
- Customer impact
- Projected Conditions/Benefits
- Timeline
- Cost
- Relationships to other solutions

There is dialog throughout the prioritization process to ensure that risks, potential impacts and other particulars are considered in the ranking of the proposed construction items. Once completed, the force ranked list is provided to Investment Delivery.



Prioritization – Investment Delivery


4) Investment Delivery Prioritization and Approval:

- A. Each Investment Reason has a budget established for the year based on capital planning.
- B. Field Engineering Manager & Inv Delivery Director review prioritized list of solutions & approve in priority order until budgeted funds are exhausted.

Prioritization: Projects approved in priority order until budget fully allocated.
 Projects entered for tracking during design and implementation.

Ranked List Reinforcements

Example



Investment Delivery Prioritization and Approval:

- Each of the Investment Reasons has a set budget for each year
- Budget level reflects investment priorities for PacifiCorp overall. Specific budget levels are allocated to Pacific Power.
- The construction/solution items are force ranked against all other construction items in that category. Projects are approved starting from highest ranked to lower ranked step by step until the annual budget has been exhausted.

“Carryover” projects from the previous year are approved first to ensure they continue toward completion. New projects then are considered for approval with remaining budget for that category.

Examples of the implementation projects currently in flight for calendar year 2022 are provided on the following slides:

- System Reinforcement – Feeder
- System Reinforcement - Substation
- Feeder Improvements
- Substation Improvements
- Functional Upgrade – Reliability (*not through regular DSP Studies*)

Distribution Investment Reasons

Distribution System Reinforcements



The most common Investment Reasons for DSP Study Solutions are:

System Reinforcement – Feeder: Used for improvements and reinforcements needed to maintain acceptable feeder support for general load growth.

Distribution Substation Reinforcements



System Reinforcement – Substation: Used for improvements and reinforcements needed to maintain acceptable substation support for general load growth.

Feeder Improvements



Feeder Improvements: Used for *functional* upgrades to a feeder (Addition or enhanced functionality to existing operational function that was not directly related to a customer reliability improvement)

Substation Improvements



Substation Improvements: *Functional* upgrades to a substation, not directly related to a customer reliability improvement. *Depending on the voltage of the substation equipment, these solutions may be either a Distribution investment or a Transmission investment.*

Reliability Improvements



Functional Upgrade – Reliability (Not From DSP Studies): Used for functional upgrades to a feeder, substation or transmission line for the purpose of improving circuit reliability that are directly associated with a customer reliability improvement.
(These items are identified and prioritized through centralized reliability analysis and specific improvement initiatives, not through regular DSP Studies)

Review 2022 Tracking Sheet Distribution System Reinforcements

| Cost Bracket Legend | | | | |
|---------------------|----------------|----------------|-------------|--------|
| Small | Med 1 | Med 2 | L | XL |
| \$0 - \$50K | \$50K - \$300K | \$300K - \$1 M | \$1M - \$3M | \$3M + |

| State | Area | District | Project Type | Project | Planned y/n | Status | Aprvd | Cost Bracket |
|-------|---------|-------------|--------------|--|-------------|--------|------------|--------------|
| OR | Central | Albany | eng | STY-4M19-0801/300700-AMSVL-RECLOSER | y | Aprv | 12/1/2021 | Med 1 |
| OR | Central | Albany | eng | LCS, 4M209 Inst Line Regs & Phase Swap | y | Pend | | Med 1 |
| OR | Central | Albany | eng | 4M16 Vine St. 795 RVR CRX & 4/0 to 477ACC | y | Pend | | Med 2 |
| OR | Central | Albany | eng | CRF 4M206 Recondutor Mainline | y | Pend | | Med 1 |
| OR | Central | Albany | eng | CRF 4M206 Configure Single Phase Loads | y | Pend | | Med 1 |
| OR | Central | Albany | eng | Murder Crk 4M243 2,100 reconductor to 4/0 (GoldFish) | y | Pend | | Med 1 |
| OR | Central | Albany | pq | IEW/Transformer upgrade:Raleigh Court | n | Aprv | 1/25/2022 | Small |
| OR | Central | Albany | pq | ALB:4M243:RECONDUCTOR GOLDFISH FARM RD | n | Aprv | 3/2/2022 | Med 1 |
| OR | Central | Albany | pq | LYN-4M70-CASCADE VIEW-ML CTY-UPGRADE XFM | n | Aprv | 5/21/2022 | Small |
| OR | Central | Bend | eng | OVR5D106:PPL/PURCELL RD RECONDUCTOR | y | Aprv | 2/16/2022 | Med 1 |
| OR | Central | Bend | eng | PNV 5D167 RECON & FUSING, PRINEVILLE | y | Aprv | 12/20/2021 | Med 1 |
| OR | Central | Bend | eng | YEW:5D325:DN7:RECONDUCTOR | y | Teco | 12/23/2021 | Med 2 |
| OR | Central | Bend | eng | CUV 5D5 Highland Ln Reg Bank Haystack FM | y | Aprv | 4/5/2022 | Med 1 |
| OR | Central | Bend | eng | BND 5D10 Recon to 1,500 u.g. | y | Aprv | 3/11/2022 | Med 1 |
| OR | Central | Bend | eng | SHP 5D241 Reconductor 4/0 to 1000 UG | y | Pend | | Med 2 |
| OR | Central | Bend | eng | OVR 5D120 Recon 4/0 | y | Aprv | 3/22/2022 | Med 1 |
| OR | Central | Bend | eng | CLV 5D94 Xfr load to 5D96 | y | Aprv | 2/16/2022 | Med 1 |
| OR | Central | Bend | eng | BND 5D10 RECONDCTOR TO 477 NW 12TH ST | y | Aprv | 6/10/2022 | Med 1 |
| OR | Central | Bend | eng | OVR 5D106 Cfg reconductor with 795 AAC | y | Aprv | 5/5/2022 | Med 1 |
| OR | Central | Bend | eng | BST 5D411 Upgrd to 3 phase | y | Aprv | 4/5/2022 | Med 1 |
| OR | Central | Bend | eng | 5D263 Swap Load to 5D265 | y | Aprv | 4/7/2022 | Small |
| OR | Central | Bend | eng | CHH 5D142 Cfg Install Reg Bank | y | Pend | | Med 1 |
| OR | Central | Bend | eng | PBT.5D263 Recon with 1/0 Al | y | Pend | | Med 1 |
| OR | Central | Bend | eng | RDD 5D226 Inst Regs SW 67th St. Winter | y | Pend | | Med 1 |
| OR | Central | Bend | eng | PBT.5D263 Recon with 1/0 Al | y | Pend | | Med 1 |
| OR | SW | Grants Pass | pq | 5R53:DN7:XFMR UPGRADE:228 S. REDWOOD HWY | n | Teco | 12/16/2021 | Small |
| OR | SW | Grants Pass | pq | IEW BETTERMENT 207 N FRONTAGE RD WC | n | Teco | 3/28/2022 | Small |

Final List:
Approved
Distribution
System Reinforcements



System Reinforcement – Feeder: Used for improvements and reinforcements needed to maintain acceptable feeder support for general load growth.

| Cost Bracket Legend | | | | |
|---------------------|----------------|----------------|-------------|--------|
| Small | Med 1 | Med 2 | L | XL |
| \$0 - \$50K | \$50K - \$300K | \$300K - \$1 M | \$1M - \$3M | \$3M + |

Review 2022 Tracking Sheet Distribution System Reinforcements (Cont.)

| State | Area | District | Project Type | Project | Planned y/n | Status | Aprvd | Cost Bracket |
|-------|---------|---------------|--------------|--|-------------|--------|------------|--------------|
| OR | SW | Klamath Falls | eng | CLA.8G65 Configure Fuse Coordination | y | Pend | | Small |
| OR | SW | Klamath Falls | eng | Nutglade 8G95 Configure Fuse Coordination | y | Pend | | Small |
| OR | SW | Klamath Falls | eng | 5L112 Burnt Wire and Fuse Repl Summers Ln | y | Aprv | 4/6/2022 | Small |
| OR | NW | Hood River | eng | WASCO:4K1 GORDON HOLLOW VOLTAGE REG | Y | Aprv | 6/4/2022 | Med 1 |
| OR | SW | Medford | eng | TOL-5R91-DN7-9370 JOHN DAY DR GOLD HILL | y | Teco | 12/16/2021 | Small |
| OR | SW | Medford | pq | TAL-5R240-DN7 960 ROSE ST, PHOENIX | n | Teco | 4/26/2022 | Small |
| OR | NW | Pendleton | eng | City of Pendleton Voltage Conversion 4KV to 12KV | y | Pend | 5/11/2021 | Small |
| OR | NW | Portland | eng | ALB:5P111:216V GRID SRV:1200 SW 12TH | y | Aprv | 12/14/2021 | Med 1 |
| OR | NW | Portland | pq | HYW:5P205:UPGRADE O/L XFMR:3134 NE 68TH | y | Pend | | Small |
| OR | NW | Portland | eng | ADW:5P604: (2) SWITCHED PAD-MT CAP BANKS | y | Pend | | Med 1 |
| OR | NW | Portland | pq | HYW:5P205:UPGRADE O/L XFMR:040 NE SKIDMO | n | Teco | 12/22/2021 | Small |
| OR | NW | Portland | pq | VRN:5P391:XFMR OVERLOAD:0101/243807 | n | Teco | 1/10/2022 | Small |
| OR | NW | Portland | pq | CUL:5P292:UPGRADE O/L XFMR:3630 NE 90TH | n | Teco | 2/4/2022 | Small |
| OR | NW | Portland | pq | CUL:5P288:UPGRADE O/L XFMR:0102/203349 | n | Teco | 2/22/2022 | Small |
| OR | NW | Portland | pq | RVL:5P278:INSL NEW XFMR:8304 NE DAVIS ST | n | Teco | 2/23/2022 | Small |
| OR | NW | Portland | pq | CUL:5P292:ROT POLE/OL ON CBL:3633 NE 90T | n | Teco | 2/24/2022 | Small |
| OR | NW | Portland | pq | MLY:5P266:XFMR OVERLOAD:01101001.0155701 | n | Teco | 2/28/2022 | Small |
| OR | NW | Portland | pq | HDY:5P158:XFMR OVERLOAD:01101001.0261600 | n | Teco | 3/17/2022 | Small |
| OR | NW | Portland | pq | KNO:5P233:XFMR OVERLOAD:01101001.0278409 | n | Teco | 3/18/2022 | Small |
| OR | NW | Portland | pq | MLY:5P266:XFMR OVERLOAD:01101001.0102206 | n | Aprv | 3/18/2022 | Small |
| OR | NW | Portland | pq | MLY:5P162:XFMR OVERLOAD:01101001.0143701 | n | Aprv | 4/25/2022 | Small |
| OR | NW | Portland | pq | CUL:5P290:XFMR OVERLOAD:01101001.0259908 | n | Aprv | 4/26/2022 | Small |
| OR | NW | Portland | pq | HYW:5P205:UPGRADE O/L XFMR:7114 NE SISKI | n | Aprv | 5/18/2022 | Small |
| OR | NW | Portland | pq | KDY:5P12:XFMR OVERLOAD:01101001.0138410 | n | Aprv | 6/8/2022 | Small |
| OR | NW | Portland | pq | #N/A | n | | 6/8/2022 | Small |
| OR | NW | Portland | pq | 5P89 FP202643 ROTTEN POLE TOP | n | Teco | 6/9/2022 | Small |
| OR | Central | Roseburg | eng | 4C36 Power Factor Correction | y | Pend | | Small |
| OR | Central | Roseburg | eng | RID 5U2 New 3 Phase Line Regulators | y | Pend | | Med 1 |
| OR | Central | Roseburg | eng | LOC 4C49 Recon 1.6 mi of #6 Cu | y | Pend | | Med 2 |
| OR | Central | Roseburg | pq | DN7 OAK 5U12 1P XFMR UPGRADE 127 NE 1ST | n | Teco | 5/19/2022 | Small |

Final List:
Approved
Distribution
System Reinforcements



System Reinforcement – Feeder: Used for improvements and reinforcements needed to maintain acceptable feeder support for general load growth.

Review 2022 Tracking Sheet Distribution Substation Reinforcements

| Cost Bracket Legend | | | | |
|---------------------|----------------|----------------|-------------|--------|
| Small | Med 1 | Med 2 | L | XL |
| \$0 - \$50K | \$50K - \$300K | \$300K - \$1 M | \$1M - \$3M | \$3M + |

| State | District | Project | In Service Date | Status | Cost Bracket |
|-------|---------------|--|-----------------|--------|--------------|
| OR | Albany | Prospect Hill-replc leakng roof | 07/30/22 | Teco | Small |
| OR | Albany | LYONS-R744-ADD ANML GRDS | 07/10/22 | Aprv | Small |
| OR | Albany | STAYTON-4M50IADD ANML GRDS | 04/21/22 | Teco | Small |
| OR | Albany | Junction City-4M102-add anml gurds | 04/21/22 | Aprv | Small |
| OR | Albany | Queen-4M258-add anml grding | 07/30/22 | Teco | Small |
| OR | Albany | Grant St-install fence and gate | 04/21/22 | Aprv | Small |
| OR | Albany | Sweet Home-CB4M94-add anml gurds | 05/30/22 | Aprv | Small |
| OR | Bend | Cleveland Install Bird Guarding | 12/31/2022 | Aprv | Med 1 |
| OR | Bend | China Hat Install Bird Guarding | 12/31/2022 | Aprv | Small |
| OR | Bend | Prineville Add Bird Guard on 2kV Bus | 12/31/2022 | Aprv | Med 1 |
| OR | Bend | Madras install bird guarding | 12/31/2022 | Aprv | Small |
| OR | Grants Pass | OIL WATER SEPARATOR GP SUB BANK3 | 10/05/22 | Aprv | Small |
| OR | Grants Pass | OIL WATER SEPARATOR GP SUB BANK4 | 10/06/22 | Aprv | Small |
| OR | Klamath Falls | Bly-Cantilever Bus Improvements | 02/22/22 | Teco | Small |
| OR | Medford | Whetstone-Install TRF & Cable Tray Water | 12/31/22 | Aprv | Med 1 |
| OR | Medford | STEVENS RD- Bird Guarding | 04/30/22 | Aprv | Small |
| OR | Roseburg | Dixonville:Line 39 Rpl SW 2U21,2U23,2U2A | 12/30/22 | Aprv | Med 1 |
| OR | Roseburg | Roberts Creek-BUS-Add bird guard | 12/30/22 | Teco | Small |
| OR | Walla Walla | Herm 5W602 Rpl Bird Guarding | 12/30/22 | Aprv | Small |
| OR | Walla Walla | Blalock Install bird guarding 5K40 | 12/31/22 | Aprv | Small |
| OR | Walla Walla | Joseph Sub 5W21 Deadline Check Install | 12/31/22 | Aprv | Med 1 |
| OR | Walla Walla | T32222 Rpl BirdG~Cap Arr~Nitro Reg~fan~D | 12/31/22 | Teco | Med 1 |
| OR | Walla Walla | ProsPec Point T3195 RPL N2 reg, Oil Dryo | 12/31/22 | Aprv | Med 1 |

Final List:
Approved
Distribution Substation
Reinforcements



System Reinforcement –
Substation:
Used for improvements and
reinforcements needed to
maintain acceptable substation
support for general load growth.

Review 2022 Tracking Sheet - Feeder Improvements

| Cost Bracket Legend | | | | |
|---------------------|----------------|----------------|-------------|--------|
| Small | Med 1 | Med 2 | L | XL |
| \$0 - \$50K | \$50K - \$300K | \$300K - \$1 M | \$1M - \$3M | \$3M + |

| State | District | Project Name | Status | In Service Date | Approved Date | Cost Bracket |
|-------|-------------|---|--------|-----------------|---------------|--------------|
| or | Albany | OSU-7M60-MANHOLE/LADDER REPLACEMENTSX10 | Pend | 12/31/2022 | | Small |
| or | Albany | CircleBlvdSub Discharge Monitorig Sys | Aprv | 12/31/2022 | 6/8/2021 | Med 2 |
| or | Albany | DVK:NEL:7A390:SUB RMVL:STEP DOWN XFMRS | Aprv | 12/31/2022 | 3/30/2022 | Med 1 |
| or | Albany | STY-4M370-0901/287701-STYTN-RADIAL->LOOP | Aprv | 12/31/2022 | 01/31/22 | Med 1 |
| or | Albany | VGN-4M86-2003/284004-4M90,4M28,4M75 SWTC | Aprv | 12/31/2022 | 03/14/22 | Med 1 |
| or | Albany | Vine St 4M15 Mainline Sectionalizing Pln | Aprv | 12/25/2022 | | Med 1 |
| or | Bend | Cleveland 5D94 Mainline Sectionalzing Pln | Aprv | 12/25/2022 | 04/21/22 | Med 2 |
| or | Lincoln Cit | Devils Lake 4A316 Instl Fiber Optic Cbl | Aprv | 12/31/2022 | 7/26/2021 | L |
| or | Medford | TAL-5R240-3 RECLOSER FLISR & DISTRO WORK | Pend | 12/31/2022 | | Small |
| or | Medford | Medford Distrib Automation Proj-FLISR | Aprv | 6/30/2022 | 12/16/2021 | L |
| or | Medford | Griffin Crk 12.57KV Circ 5R204-Mainline | Aprv | 2/28/2022 | 4/28/2022 | L |
| or | Portland | Russellville Dist Automation Proj-FLISR | Aprv | 3/31/2022 | 3/30/2021 | L |
| or | Portland | Portland Willamette River Crossing Proj | Aprv | 6/30/2025 | 03/28/19 | XL |
| or | Portland | OR Multi Sub SCADA Installs & Upgrades | Aprv | 12/31/2022 | | Med 1 |
| or | Portland | PPL 500 BUILDING INSTALL HV INTERRUPTERS | Pend | 12/31/2021 | | Small |
| or | Portland | PPL 700 BUILDING INSTALL HV INTERRUPTERS | Pend | 12/31/2021 | | Small |
| or | Portland | Hollywood 5P208/5P204 Mainline Sect Plan | Aprv | 12/25/2022 | | Med 2 |
| or | Roseburg | Roseburg-Glide Tap Loop Feeder Improvmnt | Aprv | 12/31/2022 | 08/18/21 | Med 2 |
| or | Roseburg | Recon Carnes 5U44 to Winston 5U49-4 Mile | Aprv | 12/31/2023 | | Med 1 |

Final List
Approved
Feeder Improvements



Feeder Improvements:
Used for *functional* upgrades to a feeder (Addition or enhanced functionality to existing operational function that was not directly related to a customer reliability improvement)

| Cost Bracket Legend | | | | |
|---------------------|----------------|----------------|-------------|--------|
| Small | Med 1 | Med 2 | L | XL |
| \$0 - \$50K | \$50K - \$300K | \$300K - \$1 M | \$1M - \$3M | \$3M + |

Review 2022 Tracking Sheet: Substation Improvements

| Project Name | 2023 Plan ISD | FERC Code | State | Region | MVA Added | Cost Bucket |
|--|---------------|-----------|-------|--------|-----------|-------------|
| Aumsville New Substation and Transmission Loop D | 6/15/2031 | D | OR | PP | 30 | XL |
| Banfield New 115kV to 12.5kV Substation- D | 6/15/2025 | D | OR | PP | 25 | XL |
| Bend Area New Substation | 6/15/2030 | D | OR | PP | | XL |
| Bend Sub Add Capacity and Transfer Load | 6/15/2029 | D | OR | PP | | XL |
| Bend Substation 400 A Switches Replacement | 5/15/2022 | D | OR | PP | 1.2 | Med 1 |
| Bond Street Add 2nd Transformer | 5/15/2025 | D | OR | PP | 25 | XL |
| China Hat Substation - Increase Capacity (25 MVA) | 10/15/2029 | D | OR | PP | 25 | L |
| Conser Road- Construct New 115kV to 20.8 kV substation D | 10/15/2022 | D | OR | PP | 30 | XL |
| Culver Sub Add Capacity | 5/15/2024 | D | OR | PP | | XL |
| Dorris Sub- Capacity solution-Transformer (9.4 MVA) | 5/15/2024 | D | OR | PP | 5 | L |
| Empire and State Street Transformer Loading | 5/15/2027 | D | OR | PP | 25 | XL |
| Fraley Capacity Solution | 6/15/2022 | D | OR | PP | 0.5 | Med 2 |
| Glendale Sub - Increase Capacity | 5/15/2026 | D | OR | PP | 12.5 | L |
| Henley Sub - Capacity Solution (New Sub - Net 19 MVA) | 11/15/2032 | D | OR | PP | 25 | XL |
| Hunters Circle Add Capacity | 6/15/2029 | D | OR | PP | | XL |
| Independence Substation Capacity Relief | 6/15/2022 | D | OR | PP | | Med 2 |
| Jefferson Sub - Increase capacity 12.5 MVA | 6/15/2022 | D | OR | PP | 7.5 | L |
| Madras Sub Add Capacity | 6/15/2029 | D | OR | PP | | L |
| Medford Sub Add Two 12.5kV Feeder Positions | 11/15/2023 | D | OR | PP | | Med 2 |
| Mill City Construct New Substation | 11/15/2024 | D | OR | PP | 25 | XL |
| Ochoco Substation Expansion D | 5/15/2031 | D | OR | PP | | XL |
| Phoenix Area: New Substation | 5/15/2029 | D | OR | PP | 25 | XL |
| Prineville Sub Construct Three Breaker Ring Bus D | 5/15/2031 | D | OR | PP | 25 | XL |
| Prospect Point Transformer High-Side Fuse Replacement | 5/15/2023 | D | OR | PP | | Med 2 |
| Redmond Area New 115-12.47 kV Substation D | 5/15/2026 | D | OR | PP | 25 | XL |
| Rickreall- Construct New substation D | 5/15/2024 | D | OR | PP | | XL |
| Rogue River Sub Capacity Relief | 5/15/2024 | D | OR | PP | | Med 2 |
| Shevlin Park Substation Increase Capacity | 5/15/2022 | D | OR | PP | 25 | XL |
| Wake Robin Ave- Construct New Substation D | 5/15/2026 | D | OR | PP | 30 | XL |

Final List
Approved
Substation
Improvements



Substation Improvements: Functional upgrades to a substation, not directly related to a customer reliability improvement.
Depending on the voltage of the substation equipment, these solutions may be either a Distribution investment or a Transmission investment.

Review 2022 Tracking Sheet: Reliability Improvements

| Cost Bracket Legend | | | | |
|---------------------|----------------|----------------|-------------|--------|
| Small | Med 1 | Med 2 | L | XL |
| \$0 - \$50K | \$50K - \$300K | \$300K - \$1 M | \$1M - \$3M | \$3M + |

| Operating Area | Circuit ID | Description | Fund Y/N | Project Type | Cost Bracket |
|----------------|------------|---------------------------------------|----------|-------------------|--------------|
| LINCOLN CITY | 4A338 | Install recloser and coordinate | Y | FIOLI | Med 1 |
| LINCOLN CITY | 4A312 | Auto splice review, zone 2 FIOI | Y | FIOLI | Small |
| LEBANON | 4M63 | Zone 2/3 FIOI and install recloser | Y | FIOLI | Med 1 |
| LEBANON | 4M204 | Install recloser and coordinate | Y | FIOLI | Med 1 |
| STAYTON | 4M19 | Install recloser and coordinate | Y | FIOLI | Med 1 |
| STAYTON | 4M120 | Visibility strips and pole protection | | Circuit Hardening | |
| HOOD RIVER | 5K44 | Install reclosers as switches | Y | Saving SAIDI | Small |
| PORTLAND | 5P274 | Visibility strips and pole protection | | Circuit Hardening | |
| PORTLAND | 5P393 | Zone 1 FIOI | Y | FIOLI | Med 1 |
| BEND/REDMOND | 5D229 | Zone 1 FIOI | Y | FIOLI | Med 1 |
| GRANTS PASS | 5R133 | Enhanced Fault Indication (EFI) | Y | EFI | Small |
| GRANTS PASS | 5R106 | Enhanced Fault Indication (EFI) | Y | EFI | Small |
| GRANTS PASS | 5R52 | Enhanced Fault Indication (EFI) | Y | EFI | Small |
| GRANTS PASS | 5R65 | Enhanced Fault Indication (EFI) | Y | EFI | Small |

Final List:
Approved
Reliability Improvements



Functional Upgrade – Reliability (Not From DSP Studies):

Used for functional upgrades to a feeder, substation or transmission line for the purpose of improving circuit reliability that are directly associated with a customer reliability improvement.

(These items are identified and prioritized through centralized reliability analysis and specific improvement initiatives, not through regular DSP Studies)

| Cost Bracket Legend | | | | |
|---------------------|----------------|----------------|-------------|--------|
| Small | Med 1 | Med 2 | L | XL |
| \$0 - \$50K | \$50K - \$300K | \$300K - \$1 M | \$1M - \$3M | \$3M + |

Review 2022 Tracking Sheet: Reliability Improvements *(Continued)*

| Operating Area | Circuit ID | Description | Fund Y/N | Project Type | Cost Bracket |
|----------------------|------------|---|----------|-------------------|--------------|
| KLAMATH FALLS | 5L19 | FIOLI and Enhanced Fault Indication (EFI) | Y | FIOLI | Med 1 |
| COOS BAY/COQUILLE | 4C41 | Recloser Replacement | Y | FIOLI | Med 1 |
| COOS BAY/COQUILLE | 4C42 | Recloser Replacement | Y | FIOLI | Med 1 |
| MEDFORD | 5R55 | Full Circuit FIOI | Y | FIOLI | Small |
| MEDFORD | 5R68 | Full Circuit FIOI | Y | FIOLI | Small |
| ROSEBURG/MYRTLECREEK | 4U5 | FIOLI and Enhanced Fault Indication (EFI) | Y | EFI | Small |
| ROSEBURG/MYRTLECREEK | 5U32 | Small FIOI and Reconfigure | Y | FIOLI | Small |
| PENDLETON | 5W202 | Full Circuit FIOI/DSP Transition | Y | FIOLI | Med 1 |
| PENDLETON | 5W201 | Full Circuit FIOI/DSP Transition | Y | FIOLI | Med 1 |
| PENDLETON | 5W402 | Full Circuit FIOI/DSP Transition | Y | FIOLI | Med 1 |
| PENDLETON | 5W406 | Pole Fire Mitigation | Y | PFM T1 | Small |
| BEND/REDMOND | 5D223 | Full Circuit FIOI | Y | FIOLI | Med 1 |
| BEND/REDMOND | 5D22 | Full Circuit FIOI | Y | FIOLI | Med 1 |
| BEND/REDMOND | 5D52 | Reconductor:Reliability | Y | Circuit Hardening | Med 1 |
| MEDFORD | 5R103 | Gang Switch | N | | Small |

**Final List:
Approved
Reliability Improvements**





Break – 10 Minutes



4) Pilot/Transitional Study Areas and Grid Needs



Preliminary Grid Needs – Pilot/Transitional Study Areas


Circuit/Area Characteristics:

- Suburban/rural feeders
 - low load density with high circuit miles
- Small conductor on the mainline, thus less load capacity and higher voltage drop
 - Does not necessarily = less DG readiness
- Historically higher DER adoption rates
 - Among Pacific Power service territory
- Ranked higher in DG capacity and readiness than other areas
 - Including necessary substation equipment

Preliminary findings/Grid Needs


Klamath Falls – Crystal Springs – 5L45

- Projected peak summer load drives overload on conductor
- Phase imbalance
- Low voltages on circuit



Pendleton – McKay – 5W856

- No grid needs due to recent investment upgrades
- Potential low voltages in outlying areas



Grid Needs – Pendleton

Circuit Details:

- Circuit 5W856 served from McKay substation
- Circuit operates at 12.47 kV
- Peak loading occurs during summer
- Daytime minimum loading occurs during the spring
- Overall Customer makeup:
 - 1,802 Total number of customers
 - 1,641 Residential
 - 28 Irrigation
 - 131 Commercial
 - 1 Industrial
 - 1 Hospital

No Grid Needs Found:

- Ad-hoc study performed during planning study cycle resolved any Grid Needs for area.

What Grid Needs could we have found if the Ad-hoc study did not occur?

Would it have been a good candidate for NWS?



Grid Needs – Pendleton

Model Scenario – Analyze the previous circuits as if the new substation and Ad-hoc study did not exist


McKay 5W856 is made up of sections of Buckaroo 5W202 and 5W203 served from Buckaroo Substation.

Scenario analyzes the two circuits without the new substation and applies the PV and EV forecast for Buckaroo 5W202 and 5W203

After removing the impact of the Ad-hoc study ...

No Grid Needs Found

Before:



After:




Grid Needs – Klamath Falls

Circuit Details:

- Circuit 5L45 served from Klamath Falls substation
- Circuit operates at 12.47 kV
- Peak loading occurs during summer
- Daytime minimum loading occurs during the spring
- Overall Customer makeup:
 - 1,499 Total number of customers
 - 1,196 Residential
 - 155 Irrigation
 - 145 Commercial
 - 3 Industrial

Grid Needs:

- Study identified an overcapacity issue causing conductor overload
- Also causes low voltage downstream




Grid Needs – Klamath Falls

Grid Need:

- Approximately 850 kW over existing conductor limit
- Occurs ~20 – 50 hours total per year in Summer ~ June through August
- Number of customers downstream of issue:
 - 511 Total customers (37% Summer kWh)
 - 461 Residential (24%)
 - 33 Irrigation (13%)
 - 17 Commercial (1%)
 - 0 Industrial (0%)


Based on the Grid Need and characteristics of circuit, there are several solutions available. All have different effects in terms of complexity, performance, and reliability.




Grid Needs – Klamath Falls

List of hypothetical solutions:


Traditional Wires Solution –
Reconductor overloaded conductor



Demand Side Management (DSM) Solution - Load reduction





Non-Wires Solution - Solar Only





Hypothetical Load Reduction

- Need critical mass of customers to participate in order to meet reduction target
- Peak Load day might require 9 or more hours of load reduction
- Needs to be adjusted for growth over time
- Amount & type of customers involved TBD



Hypothetical Solar + Storage


- Generation Study required in addition to Load Study
 - Different time of year and study assumptions
- Est 3.5 MWh needed for peak load (excluding buffer capacity), but mix of solar and PV TBD
- Needs to be adjusted for growth over time
- Advanced automated system required to control the smart inverters



Klamath Falls Grid Need and Potential Non-Wires Solutions

Klamath Falls – Crystal Springs – 5L45

- Projected peak summer load drives overload on conductor
- Phase imbalance
- Low voltages on circuit



Non-Wires Solutions PAC is Considering for evaluation

- Solar
- **Solar + Battery Storage**
- Load Control, Curtailment, Demand Response
- Targeted DSM
- Other DER

Non-Wires Solutions Proposed by Stakeholders:

Farmer’s Conservation Alliance:

- **Solar + Battery Storage**

OSSIA:

- Pilot use of **Smart Inverters**
- Pilot “Solarize Campaign”

Opportunity to Evaluate *Solar + Battery Storage, w/Smart Inverter*

- Work with local K Falls stakeholders + FCA + OSSIA
- Develop skillset to model and evaluate solar + storage and ID system impacts

2nd NWS – TBD Seek input from K Falls Stakeholders

Next Steps with Pilot Project

- Meeting with stakeholders in Klamath Falls 7/7
- Continue to engage FCA and OSSIA to refine pilot assessment
- Update models with more refined PV/EV adoption rate data from third party contractors
- Produce required equipment amounts and cost estimates

Initial Lessons Learned

DSP requires significantly more than historical approach...

- Much more Data Intensive
 - Requires new data sources and increased granularity for existing data
 - Analysis requires development of 24-hour representative curves instead of single peak point
 - Requires feeder SCADA telemetry instead of manually recorded data
 - Scaling up for DSP requires new toolsets/systems and analytical capabilities
- Broader and More Frequent Outreach
 - Significantly higher degree of community involvement
 - Discussions require deeper education to cover increasingly complex subjects
 - Expanding outreach processes to increase transparency
- Significant Changes to Internal Processes
 - Improve cross-functional/cross-department collaboration
 - Increased reporting requirements (not just DSP)
 - New groups, new responsibilities, and new procedures
 - New regulatory requirements



5) Update on Community Engagement at the State and Local Level





Overlap of Regulatory Initiatives for Stakeholder Engagement

Several Community Engagement Regulatory Initiatives that Share Similar Goals

- Engaging potentially overlapping stakeholder groups
 - UM 2005 and Order No. 20-485 - Community Engagement Plan to prepare and implement a Distribution System Plan
 - HB 2021 – Community Benefits and Impacts Advisory Group (CBIAG)
 - UM 2225 – Community engagement strategy to support HB 2021

Section 6. Utility Community Benefits and Impacts Advisory Group

(1) An electric company that files a clean energy plan under section 4 of this 2021 Act shall convene a **Community Benefits and Impacts Advisory Group**.

The members of the electric company's Community Benefits and Impacts Advisory Group will be determined by the electric company with input from stakeholders that **represent the interests of customers or affected entities within the electric company's service territory**.

Members must include representatives of environmental justice communities and low-income ratepayers and may include representatives from other affected entities within the electric company's service territory.



Community Input Group Update

PacifiCorp is committed to the formation of the Community Input Group (considering renaming **Oregon Equity Advisory Group**)

- We see great benefit to forming a single equity advisory group in Oregon that focuses on Clean Energy planning including DSP.
- We are working with stakeholders to establish a path forward as we thoughtfully consider requirements of UM 2005 and UM 2225.
- This specific group will not be formed in time to provide input on DSP Part 2 but other engagement opportunities are available to get community and stakeholder feedback prior to filing.
- As we move forward, we plan to use the Oregon Equity Advisory Group as a sounding board for the evolution of PacifiCorp's DSP process.



Statewide Engagement Strategy

- Filed **initial** customer engagement proposal with Commission on April 21, 2022
- Provided mechanisms and processes for meaningful stakeholder engagement on utility initiatives including the Distribution System Plan and the Clean Energy Plan
- Proposed a **hybrid stakeholder engagement model**
 - Relies upon existing engagement processes within IRP
 - Develops new processes for engagement
- Currently identifying a broad potential participant list to reflect representatives of Environmental Justice communities within our service territory
- PacifiCorp will engage with frontline communities, tribes, equity and environmental justice organizations, community-based organizations and others in Oregon to gauge their interest in membership
- Updated Engagement Strategy to be submitted in July (anticipated after July workshop)
- The engagement strategy will continue to be refined over time

Local Engagement – Klamath Falls

- Received three proposals for Non-wires Pilot evaluation from Farmer’s Conservation Alliance and OSSIA (covered previously).
 - Agreed to focus on Solar + Storage (with limited Smart Inverter functionality) as one of the NWS assessments.
 - Working with FCA and OSSIA to confirm assessment framework, assumptions and approach
- Also - engaging local stakeholders in Klamath Falls to participate in review of identified grid need and discuss potential solutions (including NWS)
 - Meeting with stakeholders in Klamath Falls 7/7 for background on DSP, Grid Needs and potential solutions
 - Anticipate second meeting in late July to review preliminary results from assessments and gather further input.

Planning to
Attend:

Jeremy Morris – Klamath County Public Works Department – Director
Roberto Gutierrez – Klamath Community College – President (Not available, may send delegate)
Ellsworth Lang – Tentative (Participating as Pacific Power customer)
Paul Simmons – Klamath Water Users Association – Executive Director
Heather Harder – Klamath County Chamber of Commerce – Executive Director
Randy Cox – Klamath County Economic Development Association – Executive Director
Brandon Fouler – Klamath County Emergency Management Department – Director
Joe Wall – Klamath Falls City Planner
Darin Rutledge – Klamath Falls Downtown Association – Executive Director
Christina Zamora – Klamath/Lake Community Action Service (TBD – confirming availability)

Questions?





6) Part 2 Schedule and Topics





Part 2 - Schedule and Topics

- **Schedule**

- OPUC DSP Workgroup Meetings – Expect one more meeting in late July
- Pacific Power Final DSP Workshop – July 21
- Distribution System Plan (Part 2) to be filed on August 15, 2022

- **Pacific Power July Stakeholder Workshop – Proposed Topics**

- Review refined Load Forecast including adoption for DER and EV
- Non-wires Solutions (NWS) – Review Initial Assessments
- Review highlights for Short-Term Plan



Additional Information

- DSP Email / Distribution List Contact Information
 - DSP@pacificcorp.com
- DSP Presentations
 - [Pacific Power Oregon DSP Website](#) (Now includes Spanish Language version)
- Additional Resources
 - [Pacific Power's DSP Part 1 Report](#)
 - [DSP Pilot Project Suggestion Form](#)
 - [Pacific Power's 2019 Oregon Smart Grid Report](#)
 - [Pacific Power's Oregon Transportation Electrification Plan](#)
 - [PacifiCorp's Integrated Resource Plan](#)



Thank You!

