

Docket No. UE 433
Exhibit PAC/1000
Witness: Richard A. Vail

**BEFORE THE PUBLIC UTILITY COMMISSION
OF OREGON**

PACIFICORP

Direct Testimony of Richard A. Vail

February 2024

TABLE OF CONTENTS

I. INTRODUCTION AND QUALIFICATIONS 1

II. PURPOSE OF TESTIMONY 1

III. OVERVIEW OF PACIFICORP’S TRANSMISSION SYSTEM..... 2

IV. CUSTOMER BENEFITS OF PACIFICORP’S TRANSMISSION SYSTEM..... 10

V. OVERVIEW OF INVESTMENTS 12

 A. Gateway South and Gateway West Transmission Lines15

 B. EV2024 Network Upgrades.....22

 C. Anticline 345 kV Phase Shifter.....25

 D. Gateway South Supporting Projects26

 E. Oquirrh Terminal 345 kV Line Project.....29

 F. Path C Transmission Improvement Project32

 G. Conser Road - Construct New 115 kV to 20.8 kV Substation Project33

VI. CONCLUSION..... 34

1 **I. INTRODUCTION AND QUALIFICATIONS**

2 **Q. Please state your name, business address, and current position with PacifiCorp**
3 **d/b/a Pacific Power (PacifiCorp or Company).**

4 A. My name is Richard A. Vail. My business address is 825 NE Multnomah Street, Suite
5 1600, Portland, Oregon 97232. I am the Vice President of Transmission at
6 PacifiCorp. I am responsible for transmission system planning, customer generator
7 interconnection requests and transmission service requests, regional transmission
8 initiatives, capital budgeting for transmission, transmission and distribution project
9 delivery, and administration of the Open Access Transmission Tariff (OATT).

10 **Q. Please describe your education and professional experience.**

11 A. I have a Bachelor of Science degree with Honors in Electrical Engineering with a
12 focus in electric power systems from Portland State University. I have been Vice
13 President of Transmission for PacifiCorp since December 2012. I was Director of
14 Asset Management from 2007 to 2012. Before that position, I had management
15 responsibility for a number of organizations in PacifiCorp's asset management group
16 including capital planning, maintenance policy, maintenance planning, and
17 investment planning since joining PacifiCorp in 2001.

18 **II. PURPOSE OF TESTIMONY**

19 **Q. What is the purpose of your direct testimony in this case?**

20 A. The purpose of my testimony is to describe PacifiCorp's transmission system and the
21 benefits it provides to Oregon customers, and specifically describe PacifiCorp's
22 major capital investment projects for new distribution and transmission systems
23 included in this rate case. These investments include transmission projects associated

1 with Energy Vision 2024 (Gateway South, Gateway West Segment D.1, Gateway
2 South Supporting projects, and the related generation interconnection network
3 upgrades), a new 345 kilovolt (kV) transmission line, and a new 115–20.8 kV
4 substation.

5 My testimony demonstrates that the Company’s decisions are prudent, and
6 that these investments result in an immediate benefit to PacifiCorp’s Oregon
7 customers. I recommend that the Public Utility Commission of Oregon (Commission)
8 find these investments prudent.

9 III. OVERVIEW OF PACIFICORP’S TRANSMISSION SYSTEM

10 **Q. What is the purpose of this section of your testimony?**

11 A. I provide an overview of PacifiCorp’s transmission system, transmission reliability
12 requirements, and standards and compliance mechanisms.

13 **Q. Please provide a brief overview of the purpose of PacifiCorp’s transmission
14 system.**

15 A. PacifiCorp’s transmission system is designed to reliably transfer affordable electric
16 energy from a broad array of generation resources to loads both within the
17 Company’s balancing authority areas (BAAs) and beyond, including other BAAs that
18 PacifiCorp interconnects with, and participants in the California Independent System
19 Operator’s (CAISO) Western Energy Imbalance Market (WEIM).


20 **Q. Please briefly describe PacifiCorp’s transmission system.**

21 A. As seen in the image below, PacifiCorp owns and operates approximately
22 17,770 miles of transmission lines ranging from 46 kV to 500 kV across multiple

1 western states. PacifiCorp serves nearly two million customers with over 627,000
2 customers located in Oregon.

3 **Figure 1**

PACIFICORP TRANSMISSION ROUTES



Resources depicted represent PacifiCorp's anticipated 2023 owned and customer-enabled purchase portfolio as identified in its 2019 Integrated Resource Plan. By the end of 2029, costs from coal-fired resources will not be included in rates for OR, WA and CA customers.

4 **Q. What are Balancing Authorities and BAAs?**


5 A. A Balancing Authority is the entity responsible for maintaining balance of load,
6 generation, and interchange in a specific BAA, and supports interconnection
7 frequency in real time. BAAs include all the generation, transmission, and loads
8 within a specific metered region.

1 PacifiCorp is a Balancing Authority and manages two BAAs: PacifiCorp East
2 (PACE) BAA and PacifiCorp West (PACW) BAA. The PACW BAA includes
3 interconnections with the Bonneville Power Administration (BPA), northern points of
4 CAISO, and other utilities in California, Oregon, and Washington. The PACE BAA
5 interconnects with utilities in the intermountain west and southwest, and also provides
6 access to the southern portion of the CAISO. As a Balancing Authority, PacifiCorp
7 manages the production and consumption of electricity in these areas, by ensuring
8 that there are adequate available generation resources or electricity transfers from
9 other BAAs to meet load. As seen in the figure below, there are 38 BAAs in the
10 Western Interconnection.¹

¹ Available at <https://www.wecc.org/Administrative/06-Balancing%20Authority%20Overview.pdf>.

1

Figure 2



2 **Q. How does PacifiCorp operate the two BAAs?**

3 A. PacifiCorp separately balances each BAA for energy and load. To optimize dispatch
4 for the benefit of customers, PacifiCorp dispatches generation across both BAAs to
5 serve load across the entire system. Deliveries of energy over PacifiCorp's
6 transmission system are managed and scheduled in accordance with the Federal
7 Energy Regulatory Commission's (FERC) requirements. The flexibility of
8 PacifiCorp's integrated transmission system provides options for optimizing dispatch
9 to serve load and designating units for holding reserves, and provides for additional
10 reliability during planned or unplanned generation outages. PacifiCorp also provides
11 transmission service across both BAAs, meaning that a transmission customer can

1 purchase transmission service from any point in one BAA to the other BAA, for a
2 single tariff rate.

3 **Q. Please describe PacifiCorp's responsibility for maintaining open access to its**
4 **transmission system and creating stakeholder transmission planning processes.**

5 A. In 1996, the FERC required transmission system owners like PacifiCorp to provide
6 non-discriminatory access to their transmission systems for all transmission
7 customers.² FERC expanded this open-access policy in 2011 by requiring
8 transmission system owners to create regional, inter-regional, and local transmission
9 planning processes.³

10 Under these authorities, the Company is required to provide
11 non-discriminatory and reliable transmission and interconnection service according to
12 the rates, terms, and conditions of PacifiCorp's OATT, and must engage in
13 participant-driven planning processes covering its six-state transmission footprint.⁴
14 These planning processes incorporate economics, reliability, and public policy inputs
15 and requirements to develop comprehensive transmission development strategies.⁵

16 Where a request for transmission service cannot be reliably provided on the
17 existing system, the Company's OATT and FERC policies require the Company to
18 construct and expand its system to provide FERC-jurisdictional transmission and

² See, *In re Open Access Transmission Services*, Order No. 888, 75 FERC ¶ 61,080 (May 10, 1996).

³ See, *In re Transmission Planning and Cost Allocation*, Order No. 1000, 136 FERC ¶ 61,051 (Jul. 21, 2011).

⁴ See, PacifiCorp's Open Access Transmission Tariff Volume No. 11, Attachment K (updated Aug. 31, 2022) (available https://www.oasis.oati.com/woa/docs/PPW/PPWdocs/20230208_OATTMaster.pdf).

⁵ See, PacifiCorp's Open Access Transmission Tariff Volume No. 11, Attachment K (updated Aug 23, 2023) (available https://www.oasis.oati.com/woa/docs/PPW/PPWdocs/20230823_OATTMaster.pdf)
https://www.oasis.oati.com/woa/docs/PPW/PPWdocs/20230208_OATTMaster.pdf).

⁵ See, e.g., PacifiCorp's Local Transmission System Plan (2022-2023 Biennial Cycle) (Dec. 31, 2023) (available

https://www.oasis.oati.com/woa/docs/PPW/PPWdocs/PacifiCorp_Local_Transmission_System_Plan_2022-2023_Report_Dec_31.pdf).

1 interconnection service.⁶ This obligation to construct transmission facilities in
2 response to transmission or interconnection service requests applies to both newly
3 identified facilities and planned system expansions or upgrades.⁷

4 **Q. Please describe PacifiCorp’s responsibility for maintaining reliability on its**
5 **transmission system.**

6 A. In 2005, Congress directed the FERC to establish reliability standards to ensure the
7 safe and reliable operation of the Nation’s Bulk Electric System (BES).⁸ The
8 following year, the FERC adopted rules to implement the statute,⁹ and delegated these
9 responsibilities to the North American Electric Reliability Corporation (NERC).¹⁰

10 NERC proceeded to establish various reliability standards, including
11 transmission system planning performance requirements (TPL Standards). NERC’s
12 TPL Standards establish, among other things, “Transmission system planning
13 performance requirements within the planning horizon to develop a Bulk Electric
14 System (BES) that will operate reliably over a broad spectrum of System conditions

⁶ PacifiCorp’s OATT, §§ 28.2 and 15.4 (reflecting FERC’s pro forma tariff and requiring PacifiCorp to construct facilities as necessary to reliably provide requested transmission service); *In re Standardized Generator Interconnection Agreements and Procedures*, Order No. 2003, 104 FERC ¶ 61,103 at 767 (2003) (explaining that FERC’s pro forma interconnection services “provide for the construction of Network Upgrades that would allow the Interconnection Customer to flow the output of its Generating Facility onto the Transmission Provider’s Transmission System in a safe and reliable manner.”); *In re Preventing Undue Discrimination and Preference in Transmission Service*, Order No. 890, 118 FERC ¶ 61,119 at 814 (2007) (explaining that despite certain policy reforms, transmission providers “will continue to be obligated to construct new facilities to satisfy a request for service if that request cannot be satisfied using existing capacity”).....

⁷ See, *In re CAISO Tariff Revision*, 133 FERC ¶ 61,224 (2010) (OATT construction obligations attach to planned facilities identified as necessary to grant interconnection requests, stating that “[t]he fact that CAISO has voluntarily chosen to evaluate a network upgrade in its transmission planning process should not affect the obligation to build these facilities.”).

⁸ 16 USC § 824o.

⁹ *In re Electric Reliability Standards Rulemaking*, 71 FR 8662-01, Docket No. RM05-30-000; Order No. 672 (Feb. 17, 2006).

¹⁰ *In re NERC Certification*, 116 FERC ¶ 61,062 (Jul. 20, 2006), *aff’d Alcoa Inc. v. FERC*, 564 F.3d 1342 (D.C. Cir. 2009).

1 and following a wide range of probable Contingencies.”¹¹ These TPL Standards,
2 along with regional (*i.e.*, established by the Western Electricity Coordinating Council
3 (WECC)) and utility-specific planning criteria, define the minimum transmission
4 system requirements to safely and reliably serve customers.

5 **Q. How does PacifiCorp ensure compliance with NERC TPL Standards?**

6 A. The Company plans, designs, and operates its transmission system to meet or exceed
7 NERC Standards for BES and WECC Regional standards and criteria. To ensure
8 compliance with applicable TPL Standards, PacifiCorp conducts an annual system
9 assessment to evaluate the performance of the Company’s transmission system and to
10 identify system deficiencies. The annual system assessment is comprised of steady-
11 state, stability, and short circuit analyses to evaluate peak and off-peak load seasons
12 in the near-term (one-, two-, and five-year) and long-term (10-year) planning
13 horizons.¹² The assessment is performed using power flow base cases maintained by
14 WECC and developed in coordination among all transmission planning entities in the
15 Western Interconnection. These base cases include load and resource forecasts along
16 with planned transmission system changes for each of the future year cases and are
17 intended to identify future system deficiencies to be mitigated.

18 As part of these annual system assessments, corrective action plans are
19 developed to mitigate identified deficiencies, and may prescribe construction of

¹¹ See Standard TPL-001-5.1 — Transmission System Planning Performance Requirements, at A(3) (available <https://www.nerc.com/pa/Stand/Reliability%20Standards%20Complete%20Set/RSCCompleteSet.pdf>) (last accessed Winter 2023-4).

¹² Analyses consist of taking a normal system (N-0) and applying events (N-1, N-1-1, N-2, etc.) within each category (P0, P1, P2, P3, etc.) listed within the TPL Standards to identify system deficiencies. For example: An N-1-1 event describes two transmission system elements out of service at the same time, but due to independent causes. An example of an N-1-1 event would be a planned outage of one 230 kilovolt transmission line followed by an unplanned outage of any additional element in the system being used to continue service with the initial element out.

1 transmission system reinforcement projects or, as applicable, adoption of new
2 operating procedures. In certain instances, operating procedures prescribing action to
3 change the configuration of the transmission system can prevent deficiencies from
4 occurring when there are two back-to-back or concurrent (N-1-1) transmission system
5 events with allowed system adjustments performed between the two events. However,
6 the use of operating procedure actions has limitations. In particular, actions taken in
7 connection with operating procedures that are designed to protect the integrity of the
8 larger integrated transmission system in the Western Interconnection can lead to large
9 numbers of customers being at risk of an outage upon the occurrence of the second of
10 two back-to-back (N-1-1) events. An effective corrective action plan, that does not
11 over-rely on operating procedure actions, is critical to ensuring system reliability so
12 that large numbers of customers are not subjected to avoidable outage risk.

13 **Q. Is compliance with the reliability standards optional?**

14 A. No. The reliability standards are a federal requirement, subject to oversight and
15 enforcement by WECC, NERC, and FERC. PacifiCorp is subject to compliance
16 audits every three years and may be required to prove compliance during NERC or
17 WECC reliability initiatives or investigations. Failure to comply with the reliability
18 standards could expose the Company to penalties of up to \$1.29 million per day, per
19 violation.

20 Accordingly, reliability standards are a major driver for the new capital
21 investments in PacifiCorp's system transmission assets that are identified in and
22 supported by my testimony below.

1 **Q. Are there additional concerns that influence PacifiCorp's distribution and**
2 **transmission system investment decisions?**

3 A. Yes. Depending on the project, there are several factors that inform whether
4 PacifiCorp will build new distribution and transmission facilities, including increased
5 demand for transmission capacity, requests for transmission service, increased
6 demand for distribution capacity, and the age and condition of existing distribution
7 and transmission facilities. The specific concerns for the projects addressed in my
8 testimony are described in more detail below.

9 **IV. CUSTOMER BENEFITS OF PACIFICORP'S TRANSMISSION SYSTEM**

10 **Q. Please describe how the PacifiCorp transmission system benefits Oregon**
11 **customers.**

12 A. PacifiCorp's transmission system is designed to reliably transport electricity from a
13 broad array of generation resources to load across both BAAs, and the Company
14 operates a geographically diverse and expansive transmission system serving retail
15 customers in six western states. This unique geographic footprint, including over
16 17,770 miles of transmission lines, allows the Company to take advantage of
17 efficiencies and economies from both a planning and operational perspective due to,
18 among other things, retail load characteristics and variable resource diversity.
19 PacifiCorp's transmission system provides over 200 interconnections with adjacent
20 transmission provider BAAs as well as access to regional energy market hubs in
21 Washington, the California-Oregon Border, Utah, the Four Corners area, and
22 Arizona.

1 This geographic diversity, access to adjacent transmission providers and
2 BAAs, and access to regional energy market hubs allows PacifiCorp to economically
3 dispatch units across its system and transfer energy from other systems as facilitated
4 by the Company's participation in the WEIM. This expansive footprint ensures that
5 PacifiCorp is uniquely situated to access some of the nation's best wind and most
6 cost-effective solar resources to serve customer load.

7 PacifiCorp also takes advantage of its transmission system to minimize
8 operation costs related to generation reserve requirements and blackstart capability.
9 The Company is required to carry reserves to ensure system reliability in the event of
10 changes in load or system events. Instead of being required to carry reserves and
11 blackstart capability in each individual BAA, PacifiCorp is able to operate its
12 transmission as a collective system and use resources that are geographically remote
13 to meet the system requirements in all areas that PacifiCorp serves. This allows the
14 Company to engage in the most economic dispatch to lower costs for its customers.

15 **Q. Does PacifiCorp currently carry reserves in each BAA sufficient to meet that**
16 **BAA's requirements?**

17 A. Not always. PacifiCorp often meets its reserve requirements in PACW with resources
18 located in PACE. While meeting reliability standard reserve requirements is not a
19 transmission function, PacifiCorp's transmission system provides flexibility for
20 PacifiCorp to meet its reserve requirements.

1 **Q. Are investments across the system necessary to maintain PacifiCorp's**
2 **transmission system?**

3 A. Yes. The ability to flexibly use a diverse set of energy resources depends significantly
4 on the strength and reliability of PacifiCorp's transmission system to connect those
5 resources to PacifiCorp's retail customers in all six states. Transmission system
6 outages and other real-time operation constraints can unnecessarily burden the
7 transmission system when corrective action plans are required to comply with NERC
8 and WECC reliability authorities. Increasing PacifiCorp's transmission system
9 capacity enhances reliability, allows more generation to interconnect to serve
10 customer load, and provides flexibility in designating generation resources for reserve
11 capacity to comply with mandatory reliability standards.

12 **Q. Can the benefits of a reliable system be easily quantified?**

13 A. No. Reliability is, essentially, the absence of system disruptions. It is very difficult to
14 quantify the benefit of reliability investments. That said, the access to different
15 regions and redundancy in operations provides reliable service under a variety of
16 conditions that benefits all PacifiCorp's customers.

17 **V. OVERVIEW OF INVESTMENTS**

18 **Q. What specific distribution and transmission system investments are you**
19 **addressing in your testimony?**

20 A. My testimony addresses PacifiCorp's major planned distribution and transmission
21 system projects that will go in-service during the test period for this rate case. Each of
22 these investments will increase PacifiCorp's load serving capability, enhance
23 reliability, conform with NERC Reliability Standards, improve transfer capability

1 within the existing system, relieve existing congestion, and interconnect and integrate
2 new wind resources into PacifiCorp's transmission system. These projects include:

- 3 • The Gateway South Segment F Aeolus to Mona/Clover 500 kV and Gateway
4 West Segment D.1 Windstar to Aeolus 230 kV Transmission Lines;
- 5 • The EV2024 Generation Interconnection Network upgrades;
- 6 • The Anticline 345 kV Phase Shifter;
- 7 • Gateway South Supporting Projects;
- 8 • The Oquirrh Terminal 345 kV Line Project.;
- 9 • The Path C Transmission Improvements Project; and
- 10 • The Conser Road- Construct new 115 kV to 20.8 kV Substation Project.

11 **Q. What are the projected investment costs and their anticipated in-service dates?**

12 A. Please see the table below for the total-Company costs and in-service dates for each
13 project. These amounts include costs for engineering, project management, materials
14 and equipment, construction, right-of-way, and an allowance for funds used during
15 construction. These costs are detailed in the testimony and exhibits of Company
16 witness Sherona L. Cheung. The in-service dates are based on our current best
17 available information at the time of preparing this case.

TABLE 1

Project	Total-Company Cost (million)	Oregon-Allocated Cost (million)	Final In-Service Date
Gateway South	\$2,097.4	\$563.9	December 2024
Gateway West Segment D.1	\$288.0	\$77.4	Various - 2024
EV2024 Network upgrades	\$40.1	\$10.8	Various - 2024
Anticline 345 kV Phase Shifter	\$133.5	\$35.9	November 2024
Gateway South Supporting Projects	\$20.2	\$5.4	December 2024
Oquirrh Terminal 345 kV Line	\$75.8	\$20.4	November 24
Path C Transmission Improvements	\$31.3	\$8.4	May 2024
Conser Road - Construct new 115 kV to 20.8 kV Substation	\$15.0	\$15.0	September 2023

1 **Q. Will PacifiCorp’s OATT transmission customers pay their proportional share of**
2 **these assets?**

3 A. Yes. Transmission customers pay for transmission and ancillary services through the
4 Company’s transmission formula OATT rate.¹³ Formula rates are updated by the
5 Company’s annual transmission revenue requirement (ATRR) filing that includes the
6 total cost of providing firm transmission service over the test year.¹⁴ This includes all
7 transmission system investments made by the Company, a return on rate base, income
8 taxes, expenses, and certain revenue credits, among other specific elements and
9 adjustments.¹⁵ Transmission assets, including the capital expenditures described in
10 this rate case, will be included in the Company’s annual ATRR filing when each asset
11 is placed in service, weighted by months in service as necessary. This annual filing

¹³ *In re PacifiCorp’s Application for Formula Rates*, 143 FERC ¶ 61,162 (May 23, 2013) (letter order approving settlement agreement establishing formula rate).

¹⁴ *See, e.g.*, PacifiCorp’s OATT Volume No. 11, Attachment H: ATRR for Network Integration Transmission Service, at 326–365 (available https://www.oasis.oati.com/woa/docs/PPW/PPWdocs/20230208_OATTMaster.pdf).

¹⁵ *Id.* at Attachment H-2: Formula Rate Implementation Protocols, at 366–386 (available https://www.oasis.oati.com/woa/docs/PPW/PPWdocs/20230208_OATTMaster.pdf); *See, e.g.*, *In re PacifiCorp’s 2022 Transmission Formula Annual Update*, Docket No. ER11-3643 (May 13, 2022) (available https://www.oasis.oati.com/woa/docs/PPW/PPWdocs/2022_Annual_update-Formula_rate_filing.pdf).

1 results in a wholesale customer rate by dividing the total ATRR by firm transmission
2 demand. This rate is then assessed against PacifiCorp's transmission customers.¹⁶

3 **Q. Do PacifiCorp's Oregon retail customers receive an offsetting revenue credit for**
4 **a portion of the transmission revenue received under PacifiCorp's OATT?**

5 A. Yes. A portion of PacifiCorp's transmission revenues are credited to the Company's
6 state retail customers. Under this approach, the Company allocates 100 percent of its
7 transmission costs to both state retail and FERC-jurisdictional customers. The FERC,
8 through the Company's ATRR filings, determines the appropriate amount to be
9 recovered from PacifiCorp's wholesale customers. This same amount is then credited
10 to PacifiCorp's retail customers. This ensures that PacifiCorp recovers its
11 transmission expenditures, and both wholesale and retail customers only pay their
12 proportional share of the Company's transmission system.

13 The testimony below provides additional discussion and details for each of
14 transmission investments that the Company seeks rate recovery for in this proceeding.

15 A. **Gateway South and Gateway West Transmission Lines**

16 **Q. Please describe the Energy Gateway Transmission Expansion.**

17 A. In 2007, PacifiCorp launched the Energy Gateway Transmission Expansion, a multi-
18 year strategy to add approximately 2,000 miles of new transmission lines across the
19 west. To date, three major segments of Energy Gateway are complete and in
20 service.¹⁷ After over a decade of planning, the Company now proposes to move
21 forward with constructing the Gateway South and a portion of Gateway West lines

¹⁶ See *PacifiCorp's Transmission and Ancillary Services Rates* (effective Jun. 1, 2022) (available https://www.oasis.oati.com/woa/docs/PPW/PPWdocs/Rate_Table_20220601-more_decimals.pdf).

¹⁷ See generally <https://www.pacificorp.com/transmission/transmission-projects/energy-gateway.html>

1 (D.1).¹⁸ The following graphic provides an overview of the Energy Gateway
 2 Transmission Expansion generally, and the Gateway South and Gateway West lines
 3 specifically.

4 **Figure 3**



This map is for general reference only and reflects current plans.
It may not reflect the final routes, construction sequence or exact line configuration.

5 **Q. Please describe the Gateway South Transmission Project.**

6 **A.** The Gateway South Project includes the following elements:

- 7
- 8
- A 416-mile, high voltage 500 kV transmission line from the Aeolus substation, near Medicine Bow, Wyoming to the Clover substation near Mona, Utah.
- 9
- Rebuilding certain 345 kV transmission facilities in and around the Mona and Clover substations in Utah.
- 10

¹⁸ See, e.g., PacifiCorp 2021 Integrated Resource Plan, Vol. 1, Ch. 4 – Transmission, at 83–102 (available <https://www.pacificorp.com/content/dam/pcorp/documents/en/pacificorp/energy/integrated-resource-plan/2021-irp/Volume%20I%20-%209.15.2021%20Final.pdf>.)

- 1 • Two new series compensation stations.
- 2 • Expansion of the Aeolus, Anticline, and Clover substations along with
- 3 modifications to the Mona substation.
- 4 • Additional shunt capacitors at Bonanza (Utah), Riverton and Mustang
- 5 (Wyoming) substations.
- 6 • Additions and modifications to various remedial actions schemes, voltage
- 7 controllers and control schemes necessary to ensure protection and control of the
- 8 grid after integration of Gateway South.

9 **Q. Please describe the Gateway West Segment D.1 Transmission Project.**

10 A. Gateway West Segment D.1 includes the following elements:

- 11 • A new 59-mile high-voltage, 230 kV transmission line from the Shirley Basin
- 12 substation in southeastern Wyoming to the Windstar substation near Glenrock
- 13 Wyoming.
- 14 • Rebuild of the existing Dave Johnston – Amasa – Difficulty – Shirley Basin
- 15 230 kV transmission line, which runs approximately 57 miles from the Shirley
- 16 Basin substation in southeastern Wyoming to the Dave Johnston substation near
- 17 Glenrock, Wyoming.
- 18 • A new 230 kV Heward substation adjacent to the Difficulty substation.
- 19 • Construction of four miles of high voltage 230 kV transmission line from the
- 20 Aeolus substation to the Freezeout substation near Medicine Bow, Wyoming.
- 21 • Additions to the Shirley Basin, Dave Johnston, and Windstar substations.

22 **Q. Please explain why the Gateway South and Gateway West Transmission Projects**
23 **(collectively, the Transmission Projects) are needed.**

24 A. The Transmission Projects are an important component of the Company’s Energy
25 Gateway Transmission Expansion, and Gateway South has long been recognized as a
26 key transmission segment in the region’s long-term transmission planning. These
27 lines will provide substantial customer benefits.

1 For example, the Company needs additional resources to serve load by 2024,
2 and the Transmission Projects enable new, cost-effective Wyoming generation
3 resources to fill this need: these Transmission Projects allow the Company to
4 interconnect up to approximately 2,030 megawatts (MW) of new resources. These
5 projects will also improve reliability of the transmission system by providing capacity
6 between Gateway West and Gateway Central and relieve transmission congestion on
7 the existing Wyoming transmission system. The Gateway South line also allows
8 transfers of up to 1,700 MW from eastern Wyoming to central Utah.

9 **Q. Is the increased capacity provided by the Transmission Projects consistent with**
10 **the Company’s obligation to provide transmission service under its OATT?**

11 A. Yes. PacifiCorp adhered to OATT processes when identifying the need for these
12 transmission projects. In response to nearly 2,500 MW of transmission and
13 interconnection service requests, the Company determined that the Transmission
14 Projects were necessary to facilitate the various requests because PacifiCorp lacked
15 adequate transmission capacity. As a result the Transmission Projects have been
16 included in multiple FERC-jurisdictional executed contracts. For example, PacifiCorp
17 has executed 13 contracts with third-party customers that require constructing one or
18 both of the Transmission Projects, including a transmission service agreement that
19 requires construction of Gateway South to reliably provide 500 MW firm point-to-
20 point transmission service beginning by the contract start date of January 1, 2025.
21 The Transmission Projects are lynchpins in PacifiCorp’s ability to meet its obligation
22 to grant generator interconnection service and transmission service under the OATT.

1 The Transmission Projects will also enhance the Company's ability to comply
2 with mandated NERC and WECC reliability and performance standards. Congestion
3 on the current transmission system in eastern Wyoming limits the ability to deliver
4 energy from eastern Wyoming to PacifiCorp load centers in Wyoming, Idaho, Utah,
5 and the Pacific Northwest.

6 **Q. Do the Transmission Projects increase the amount of generation that can be**
7 **interconnected and delivered across the Company's transmission system?**

8 A. Yes. The Transmission Projects will allow the Company to interconnect an additional
9 2,030 MW of generation resources in eastern Wyoming and increase the system
10 transfer capability by approximately 875 MW from the Windstar/Dave Johnston area
11 south to Shirley Basin/Aeolus. This will create approximately 1,700 MW of
12 incremental transfer capability from eastern Wyoming (Aeolus) to the central Utah
13 energy hub (Mona/Clover).

14 **Q. Did the Company consider alternatives to Transmission Projects?**

15 A. Yes. PacifiCorp and Northern Grid (then the Northern Tier Transmission Group, an
16 unincorporated association of entities that promotes coordinated, open, and
17 transparent transmission planning and facilitates compliance with FERC transmission
18 planning and reliability standards for the Pacific Northwest and Intermountain West)
19 evaluated one alternative. This alternative analyzed one 345 kV line with bundled
20 conductor from Aeolus to Anticline (138 miles), and two 345 kV lines with bundled
21 conductors from Anticline to Populus (approximately 198 miles each), along with
22 other supporting mitigation such as transformers and shunt capacitors at different
23 substations.

1 These analyses indicated that the alternatives were less beneficial compared to
2 the Gateway West and South projects for two reasons. First, these alternative lines
3 would reduce the number of renewable resources that could be interconnected to
4 eastern Wyoming by approximately 1,100 MW compared to Gateway West and
5 South.

6 Second, this alternative also showed additional reliability issues on the
7 transmission system between Rock Springs and Monument, and also between
8 Populus and Terminal, that would have to be mitigated to comply with relevant
9 reliability standards. This would result in additional cost burdens. Like the Aeolus to
10 Clover line, this alternative does not provide an adequately diverse path for
11 PacifiCorp's network loads.

12 These two considerations led the Company to conclude that Gateway West
13 and South were more beneficial.

14 **Q. If it did not construct the Transmission Projects, would the Company be able to**
15 **provide the roughly 2,500 MW of interconnection and transmission service**
16 **without constructing additional facilities?**

17 A. No, it would not be possible to provide these requests for interconnection and
18 transmission services with PacifiCorp's existing BES. For example, to grant only the
19 500 MW transmission service request, the Company would be required to construct a
20 230 kV line at a cost of approximately \$1 billion. To grant the transmission and
21 interconnection service requests, consistent with the Company's OATT, would
22 require construction of the functional equivalent of the Transmission Projects.

1 **Q. Has the Company obtained all necessary permits and rights-of-way (ROW) for**
2 **the Transmission Projects?**

3 A. Yes. All permits and ROW for both Gateway South and Gateway West Segment D.1
4 have been secured.

5 **Q. When did PacifiCorp begin construction of the Transmission Projects?**

6 A. Once the Company received necessary permits and ROW, the Company began
7 construction of the Gateway South Project in June 2022, and late September 2022 for
8 Gateway West Segment D.1.

9 **Q. Is the Company confident that the Transmission Projects will be in service by**
10 **2024?**

11 A. Yes. To manage construction schedule risk, the Company has structured and managed
12 the projects on firm, date-certain, fixed-price, turnkey contracts. Construction
13 contractors and equipment suppliers will be held to key construction and delivery
14 milestones, guarantees, and development of compressed schedule mitigation plans, if
15 required. The construction remains on-track and on schedule.

16 **Q. Are the Transmission Projects currently on budget?**

17 A. Yes. The project budgets based on contractual provisions require fixed cash flows
18 that are assessed monthly against confirmed construction progress, in addition to
19 identification and mitigation of project risks that could stall or delay completion. To
20 date, almost 18 months from starting construction, both projects remain on budget.

21 **Q. What are the remaining major milestones for the Transmission Projects?**

22 A. Key milestones remaining before the in service date for these two projects include:
23

- Complete all wound core device deliveries by June 2024.

- 1 • Complete construction of the 500 kV transmission line and reconstruction of
2 the 230 kV transmission line by October 2024.
- 3 • Complete all communications network additions and upgrades by October
4 2024.
- 5 • Complete construction of the 230 kV Windstar to Shirley Basin line by
6 October 2024.
- 7 • Complete reconstruction of the 230 kV transmission line by November 2024.
- 8 • Complete commissioning and placed in-service in fourth quarter of 2024.

9 The Transmission Projects are on track to achieve each milestone.

10 **B. EV2024 Network Upgrades**

11 **Q. What are network upgrades?**

12 A. Network upgrades are the modifications or additions to transmission-related facilities
13 that are integrated with and support PacifiCorp's overall Transmission System for the
14 general benefit of system users.¹⁹

15 **Q. Please explain how network upgrade cost allocation works under the OATT.**

16 A. When PacifiCorp receives a request for generation interconnection or transmission
17 service, the Company completes various studies to determine what new facilities or
18 upgrades to existing facilities are required to accommodate the request.²⁰ The studies
19 classify any required additions to support the requested service into two categories:
20 direct assigned or network upgrade. Direct-assigned assets only benefit, or are used
21 solely by, the customer requesting generator interconnection or transmission service.
22 Those costs are directly assigned and paid for by that customer and will not be
23 included in either the Company's ATRR or retail rates. Network upgrades, on the

¹⁹ See, e.g., PacifiCorp's OATT Volume No. 11, § 1.27 (available
https://www.oasis.oati.com/woa/docs/PPW/PPWdocs/20230208_OATTMaster.pdf)

²⁰ *Id.* §§ 38–43.

1 other hand, benefit all customers that use the transmission system. Network upgrade
2 costs can be included in PacifiCorp's ATRR, and ATRR revenues, are then credited
3 to PacifiCorp's retail customers in each state.²¹

4 **Q. Is the Company requesting recovery of any Generation Interconnection Network**
5 **Upgrades?**

6 A. Yes. There are five generation interconnection projects that were selected from a
7 recent request for proposal to interconnect 1,640 MW of new wind generation to the
8 Company's transmission system in eastern Wyoming. The request for proposal
9 process and the resulting resources selected are described in the testimony of
10 Company witness Rick T. Link. A separate generation interconnection agreement was
11 negotiated and signed for all five projects, and each will require generation
12 interconnection network upgrades to interconnect and integrate with PacifiCorp's
13 system. These projects include:

- 14 • Q0409 Boswell Springs Wind. This project is a 320 MW wind facility that
15 will interconnect to the existing Freezeout 230 kV substation near Aeolus and
16 is planned to be in service by December 31, 2024. This project includes a new
17 breaker at the Freezeout substation, and a new remedial action scheme and
18 communications equipment at Aeolus substation.
- 19 • Q0713 Cedar Springs IV Wind. This project is a 350 MW wind facility that
20 will interconnect to the existing Yellowcake 230 kV substation near Windstar,
21 and is planned to be in service on January 15, 2025. This project includes
22 construction of a new line position at the Yellowcake substation, including the
23 installation of three new 230 kV circuit breakers, and requires a new
24 microwave system and approximately 18 miles of fiber optic cable between
25 Yellowcake and Windstar substations.
- 26 • Q0785 Anticline Wind. This project is a 100 MW wind facility that will
27 interconnect to a new substation on PacifiCorp's Casper – Claim Jumper
28 230 kV line and is planned to be in service on December 31, 2024. This
29 project includes a new three breaker ring bus substation on the Casper – Claim

²¹ *Id.* 47.

1 Jumper 230 kV line, substation loop in on transmission line, communications
2 upgrade at Casper substation, and Main Grid operations center updates.

- 3 • Q0835 Rock Creek Wind. This project is a 190 MW wind facility that will
4 interconnect to PacifiCorp's existing Foote Creek 230 kV substation and is
5 planned to be placed in service on December 15, 2024. This project includes
6 expansion of substation, bus, and line position at Foote Creek substation,
7 expansion for new breaker and line positions at Freezeout and Aeolus
8 substations, construction of new approximately 3.5 miles long 230 kV
9 transmission line between Aeolus and Freezeout substations.

- 10 • Q0836 Rock Creek Wind 2. This project is a 400 MW wind facility that will
11 interconnect to PacifiCorp's existing Aeolus 230 kV substation and is planned
12 to be placed in service on December 15, 2024. This project includes a new bay
13 for a 230 kV line terminal at Aeolus substation.

14 **Q. Why are these projects classified as network upgrades, and not directly assigned**
15 **assets?**

16 A. The interconnection study for each project indicated that these upgrades would
17 provide system-wide benefits. Under PacifiCorp's OATT, this requires the Company
18 to include these costs in the Company's ATRR, as opposed to directly assigning these
19 costs to each project. Accordingly, the network upgrade costs for each of these
20 projects are reflected in their respective Large Generator Interconnection Agreements.

21 **Q. Is the Company confident that it can manage any construction schedule risk and**
22 **deliver the network upgrades for the new wind facilities by the planned**
23 **in-service dates?**

24 A. Yes. To manage construction scheduling risk, the Company structured each network
25 upgrade contract on a firm, date-certain, turnkey contract basis. Construction
26 contractors and equipment suppliers are being held to key construction and delivery
27 milestones and development of compressed schedule mitigation plans, if required.

28 The Company also established construction contract completion dates and

1 backstopped them with guarantees. To date, the remaining network upgrades remain
2 on track for planned in-service dates.

3 **C. Anticline 345 kV Phase Shifter**

4 **Q. Please describe the proposed Anticline 345 kV Phase Shifter Project.**

5 A. The Anticline 345 kV Phase Shifter project will install four 345 kV phase shifting
6 transformers (533.3/597.3 megavolt amperes (MVA) each (summer normal/4-hour
7 emergency), +40/-40 degrees) at Anticline substation, near Point of Rocks, Wyoming.

8 **Q. Please explain why these projects are needed and beneficial.**

9 A. With the addition of the Gateway South Project, the phase shifters at Anticline are
10 needed to enhance Wyoming transmission utilization and maximize the production of
11 eastern Wyoming wind generation. By utilizing the phase shifters at Anticline, flows
12 on the Aeolus – Bridger/Anticline line can be actively controlled to unload the
13 underlying 230 kV system west of Aeolus, and manage flows on the Aeolus – Clover
14 500 kV (Gateway South) and the Aeolus-Anticline 500 kV transmission line to within
15 its limits. If the Gateway South transmission path rating limit is exceeded, eastern
16 Wyoming wind generation must be curtailed, and the phase shifters help prevent
17 unnecessary curtailment.

18 **Q. Did PacifiCorp consider alternatives to investing in the Anticline 345 kV Phase
19 Shifter project?**

20 A. Yes. Other transmission path power flow control methods, such as multi-segment
21 series capacitors, has previously been investigated; however, the installation of phase
22 shifting transformers at Anticline to provide active control flows on the Anticline –
23 Bridger 345 kV line was shown to be the most efficient and cost effective. In

1 addition, adding more than 70 percent series compensation on the transmission line is
2 not preferred, and it would limit the applicability of this proposed alternative.

3 **D. Gateway South Supporting Projects**

4 **Q. Please describe the Gateway South Supporting Projects.**

5 A. The Gateway South (Aeolus – Clover) Project is a long high voltage transmission line
6 that required additional supporting projects to enhance Wyoming transmission
7 utilization and maximize the production of eastern Wyoming wind generation. These
8 additional supporting projects include:

- 9 • Install one 41.6 megavolt amperes reactive MVAR shunt capacitor bank at
10 Riverton 230 kV substation, install two 30 MVAR shunt capacitor banks at
11 Mustang 230 kV substation, and one 60 MVAR shunt capacitor bank at
12 Bonanza (Deseret owned) 138 kV substation. These facilities help maintain
13 the flows and voltage reliability at each substation.
- 14 • Modification to the Aeolus remedial action scheme (RAS) to add Gateway
15 South line logic and additional wind projects as part of the wind selection
16 logic.
- 17 • Modifications to the Bridger RAS to support additional wind generation.
- 18 • Implementation of a new fast voltage controller (FVC) at Aeolus substation
19 prevent high voltages for the loss of 500kV lines under heavy load scenarios.
- 20 • Modification of the existing Master Grid Controller at Aeolus, to
21 accommodate the addition of the new windfarms.
- 22 • Development of operating procedures to mitigate N-1-1 loss of the two
23 230 kV paths from Dave Johnston/Windstar area to Aeolus.
- 24 • Modifications to the Energy Management System (EMS) to support
25 monitoring flows on the transmission paths.

26 **Q. Please explain why these projects are needed and beneficial.**

27 A. The shunt capacitor banks will support additional power flows through the

1 Riverton – Wyopo 230 kV and Mustang – Bridger 230 kV lines under outage
2 conditions, and will also alleviate low voltage issues. This is because the loss of
3 transmission lines from Dave Johnston/Windstar to the Aeolus area diverts all the
4 energy resources in the Dave Johnston/Windstar area towards the Riverton - Wyopo
5 230 kV and Mustang – Bridger 230 kV lines, and causes low voltages on the Riverton
6 and Mustang 230 kV buses. Without the shunt capacitor banks, the outage would
7 require significant reductions in wind generation to maintain power flows and voltage
8 reliability at the Mustang and Riverton 230 kV buses. The Bonanza shunt capacitor
9 bank is owned by Deseret, and an agreement has been signed for them to install with
10 PacifiCorp reimbursing their costs.

11 Modifying the Aeolus RAS is required to add the Gateway South line in the
12 logic, to trip 627 MW of wind generation for the loss of any of the Gateway South
13 elements from Aeolus to Clover. For the Bridger RAS, until the Bridger units are
14 available for tripping, minor changes might be required, but if the Bridger units are
15 retired while keeping the 2400/2200 MW path limit, then additional wind generation
16 will have to be included in the Bridger RAS for tripping.

17 The Aeolus FVC is designed to prevent high voltage at Aeolus 500 kV and
18 Aeolus 230 kV bus for the loss of either line. Because Gateway South requires three
19 new 200 MVAR shunt capacitors on the Aeolus 500 kV and 230 kV substations,
20 planning studies have demonstrated that the loss of either 500 kV line could result in
21 high voltages if the shunt capacitors banks are not tripped quickly. Manually tripping
22 shunt capacitors is a complex task, because it depends on evaluating real-time and
23 anticipated power flow levels, and which 500 kV lines are in-service. It is difficult to

1 implement this logic as part of a comprehensive protection scheme. Instead, the
2 Aeolus FVC is designed to automatically and quickly trip the shunt capacitor banks
3 and prevent high voltages for the loss of 500 kV lines.

4 Developing an operating procedure for the Windstar area for the N-1-1 loss of
5 the two 230 kV transmission paths from Dave Johnston/Windstar area to Aeolus
6 would require generation curtailment to prevent thermal overloads and low voltage
7 issues in the Casper, Riverton, Thermopolis, and Mustang areas. The operating
8 procedure will identify the list of generators that can be curtailed along with the list of
9 contingencies for which the curtailment may be necessary depending on dispatch
10 scenarios.

11 **Q. Did PacifiCorp consider alternatives to these supporting projects?**

12 A. Yes. There were two alternatives considered instead of installing of the shunt
13 capacitors at Mustang and Riverton. The first was additional transmission from the
14 Dave Johnston/Windstar area to Aeolus, similar to Gateway West segment D.1
15 (Windstar – Shirley Basin), and the second was installing a +/- 100 MVAR Static Var
16 Compensator at Casper. The installation of the shunt caps however was deemed to be
17 the most efficient and cost-effective option.

18 The Company also considered alternatives to the Aeolus RAS modification
19 requirements, which would result in additional transmission from Aeolus – Clover.
20 This would be a significant cost compared to modification of the RAS. In addition,
21 without the RAS modification, the amount of renewable resources that could be
22 integrated into the eastern Wyoming system would be reduced by approximately
23 400-500 MW.

1 The Company also considered alternatives for the Jim Bridger RAS
2 modification, which would result in additional new transmission between Jim Bridger
3 and Populus (approximately 200 miles of new 345 kV line). Similar to the Aeolus
4 RAS modification, this would be a significant cost as compared to the modification of
5 the RAS. In addition, without the RAS modification, PacifiCorp would not be able to
6 achieve the full path rating on Bridger West under different operating conditions such
7 as high wind and low Bridger generation.

8 **E. Oquirrh Terminal 345 kV Line Project**

9 **Q. Please describe the Oquirrh Terminal 345 kV Line Projects.**

10 A. This project involves the construction of a new 14-mile double circuit, 345 kV
11 transmission line between the Company's Oquirrh substation in West Jordan, Utah,
12 and Terminal substation in Salt Lake City, Utah. This transmission line will link
13 together the previously completed Mona to Oquirrh and Populus to Terminal
14 transmission lines, which were both part of the Gateway Central portion of the
15 Energy Gateway Transmission Expansion.

16 **Q. Please explain why this project is needed and beneficial.**

17 A. This project mitigates transmission constraints that currently exist between the Mona
18 area and Wasatch front, and will improve system reliability and operational
19 redundancy.

20 For example, the northbound transmission capacity on the Wasatch Front
21 South (WFS) internal transmission cut plane (a 4,945 MW rating) is currently fully

1 utilized,²² and transmission planning studies show that new transmission facilities are
2 necessary to meet anticipated network load service, reliability, contractual point-to-
3 point commitments and enhance WEIM benefits. There are also ongoing requests to
4 interconnect additional renewable generation resources in southern Utah and transmit
5 the energy north that further exceed the transmission capacity on the WFS path north
6 of Mona. Additionally, the Company anticipates that future Gateway South transfers
7 into the Mona/Clover area will exacerbate an already constrained transmission
8 system, and will require the Oquirrh-Terminal double circuit line to increase
9 northbound transfers across the WFS transmission path. Finally, NERC TPL-001-4,
10 requirements P1 and P7 mandate increased transmission system reliability and
11 operational redundancy in the area under all expected operating conditions.

12 The Oquirrh – Terminal double circuit transmission line, in conjunction with
13 the companion projects, addresses each of these issues. It enhances transmission
14 system reliability and operational redundancy within the Wasatch Front by adding
15 additional capacity. This additional transmission capacity also avoids 1,800 MW of
16 curtailment to the WFS cut plane, and also a similar reduction of the equivalent
17 amount of renewable or conventional generators in southern/central Utah, that would
18 otherwise be required to reduce congestion. This increased capacity also avoids the
19 increase stress on the transmission system from Wyoming to the west and northern
20 Utah that otherwise would be used to serve load in the northwest. Additionally,
21 without this new transmission, under system-outage conditions, load shed of up to

²² Previous technical studies have determined the current WFS transfer capability to be 4945 MW, prior to addition of the Oquirrh – Terminal 345 kV line addition and associated companion projects. At 4945 MW, the WFS path is 100 percent committed (2016), prior to the addition of the Gateway South transmission project.

1 1,350 MW may be required to reduce thermal overload below its 30-minute
2 emergency rating. This could potentially increase up to 2,500 MW to bring the
3 transmission facilities below its continuous rating and normal operation without the
4 new transmission line.

5 **Q. Did PacifiCorp consider alternatives to investing in the Oquirrh Terminal**
6 **345 kV Line?**

7 A. Yes. PacifiCorp took an iterative approach for resolving system limitations to
8 increase transmission capacity on WFS cut plane. This transmission cut plane helps
9 resources from southern Utah move north to serve load, as well as export power
10 further north and to the northwest. Based on the Wasatch Front South Study Table 6
11 posted on PacifiCorp's OASIS,²³ PacifiCorp first identified an alternative mitigation
12 to resolve the same system limitation (simultaneous outage of two Oquirrh –
13 Terminal #1 & 2 345 kV lines). This alternative only allowed for a certain amount of
14 capacity increases before the same limitation was observed again, and no other
15 alternative mitigations were available to increase transmission capacity between
16 Oquirrh and Terminal other than adding new transmission. The Company's Oquirrh
17 Terminal 345 kV project adds new transmission, though provides a higher increase in
18 transmission capacity that allows additional resources to move south-to-north
19 compared to the alternative case.

²³ Available here:

https://www.oasis.oati.com/woa/docs/PPW/PPWdocs/Wasatch_Front_South_Boundary_Capacity_7_29_2021.pdf

1 **F. Path C Transmission Improvement Project**

2 **Q. Please describe the Path C Transmission Improvement Project.**

3 A. The Path C Transmission Improvement project adds a new 345/138 kV source in
4 northern Utah and southeast Idaho by looping the existing Populus - Terminal 345 kV
5 line in and out of the Bridgerland and Ben Lomond substations. The project also
6 includes upgrades at Bridgerland substation, including a 345/138 kV 700 MVA
7 autotransformer; a new 345 kV bus; three 345 kV breakers; and four 138 kV
8 breakers. This new 345/138 kV source will improve the reliability of the 138 kV
9 system, which runs parallel to Path C and will eliminate system limitations on the
10 parallel 138 kV lines. It will also help maintain Path C ratings as well as add
11 operational flexibility under outage conditions at Ben Lomond substation.

12 **Q. Please explain why these projects are needed and beneficial.**

13 A. The Path C Transmission Improvement project resolves N-2 issues that were
14 identified as part of a NERC FAC-013 Assessment of Transfer Capability for the
15 Near-Term Transmission Planning Horizon. This assessment was conducted to
16 maintain WECC Path C ratings to 1,600 MW southbound, and 1,250 MW
17 northbound. The project also adds a new 345/138 kV source in northern Utah and
18 southeast Idaho which improves the reliability of the 138 kV system, which runs
19 parallel to Path C and adds operational flexibility under outage conditions at Ben
20 Lomond substation.

1 **Q. Did PacifiCorp consider alternatives to investing in the Path C Transmission**
2 **Improvement project?**

3 A. Yes. The first alternative considered was to rebuild 6.3 miles of Oneida – Treasureton
4 line, 29.5 miles of the Treasureton – Wheelon 138 kV line, expand the Bridgerland
5 138 kV substation, and loop in the Honeyville – Wheelon 138 kV line in and out of
6 the substation. However, this alternative only resolves issues related to Path C
7 southbound flows. To resolve northbound issues on Path C, an additional rebuild of
8 22.6 miles of double circuit line from Ben Lomond – Honeyville and 9 miles of Ben
9 Lomond – White Rock 138 kV line would still be required. These alternatives were
10 higher costs than the Company’s primary choice.

11 **G. Conser Road - Construct New 115 kV to 20.8 kV Substation Project**

12 **Q. Please describe the Conser Road - Construct New 115 kV to 20.8 kV Substation**
13 **Project.**

14 A. The Conser Road New Substation project is a new 115 kV to 20.8 kV distribution
15 substation that went into service in September 2023. The new substation includes one
16 30 MVA 115–20.8 kV transformer with one switchgear and a two-stage capacitor.
17 Scope to move voltage transformers to Conser Road substation from Murder Creek
18 substation has been delayed to June 2024 due to outage scheduling.

19 **Q. Please explain why these projects are needed and beneficial.**

20 A. The new substation provides 30 MVA of initial capacity, expandable up to 120 MVA
21 of total capacity, for industrial development in the Millersburg area. This new
22 substation frees capacity at Murder Creek to supply additional load in the south
23 Millersburg and Northeast Albany area, and also frees capacity at Murder Creek for

1 the heavily loaded Queen Avenue or Vine Street substations.

2 This project, in combination with the Hazelwood Ring Bus and
3 reconductoring a 0.28-mile section of the Murder Creek to Conser Tap line (at the
4 Murder Creek end), will fully address the known TPL deficiencies in the Willamette
5 Valley transmission system, and effectively eliminate the need to perform
6 12 switching operation to change the system to a radial configuration following a
7 single contingency.

8 **Q. Did PacifiCorp consider alternatives to investing in the Conser Road - Construct**
9 **New 115 kV to 20.8 kV Substation?**

10 A. Yes. The only alternative for the distribution substation capacity issue would be to
11 construct two new distribution substations, one near Murder Creek and the other in
12 the North Albany area, however this would be a more costly solution because it
13 would require construction of a second substation.

14 **VI. CONCLUSION**

15 **Q. Please summarize your testimony.**

16 A. I recommend that the Commission conclude that the projects described above are
17 prudent.

18 **Q. Does this conclude your direct testimony?**

19 A. Yes.