

Original Sheet No. R2.1

Rule 2 GENERAL RULES AND REGULATIONS—TYPES OF SERVICE

(A) DEMAND PULSE ACCESS SERVICE:

Company will provide access to Company's metering pulses proportional to Customer's kilowatthour usage by means of Demand Pulse Relay equipment to be owned, installed and maintained by Company. The installation of Company owned Demand Pulse Relay equipment shall be conditioned on the following:

- 1. Customer enters into an agreement with Company for not less than one year and pays Company an amount as specified in Schedule 300 for installation, operation and maintenance of Demand Pulse Relay equipment.
- 2. Except for metering equipment normally furnished for Customer's load characteristics, any metering equipment or associated work that must be provided to make the Demand Pulse Relay operable, shall be by Company at Customer's expense.
- 3. The Company's billing meter installation shall, in all instances, govern in establishing Customer's energy and demand record for billing purposes.
- 4. The Company's meter used in determining the Customer's billing shall measure demand by rolling consecutive subintervals and shall not provide end of interval pulses to the Customer.
- 5. Company reserves the right, after a minimum 24 hour notification to Customer, to interrupt the supply of pulse information to perform meter tests or maintenance procedures and assumes no responsibility for the effect on the Customer's operation or equipment.
- 6. If, at any time, in Company's sole judgment, the supply of demand pulse information through the Demand Pulse Relay equipment becomes detrimental to reliable metering or to the Company's metering practices, the Company shall, after a minimum 24 hours notification to Customer, have the right to disconnect the Demand Pulse Relay equipment from its metering facilities without liability to Customer.

(continued)

Issued: December 18, 2020

Effective: January 1, 2021

Docket No. UE-191024
Issued By PacifiCorp d/b/a Pacific Power & Light Company

By: _____ Etta Lockey Title: Vice President, Regulation



Original Sheet No. R2.2

Rule 2 GENERAL RULES AND REGULATIONS—TYPES OF SERVICE

B. HIGHLY FLUCTUATION LOAD SERVICE:

All service or a portion of service which is of such short duration or of such nature that regular demand meters will not register the true or representative amount of demand required by the load. Where Customers have connected to Company's system, arc furnaces, draglines, welders, log chippers, or other equipment of a nature which repeatedly create high momentary or short period demands, such service may be furnished by Company, provided the Customer enters into an agreement to pay specified monthly demand charge in accordance with the applicable schedule for deliveries of electric power and energy. For purposes of determining the monthly billing demand, the Company reserves the right to:

- 1. Install such metering as Company may require for measuring or computing the demand over a shorter interval than specified in the applicable schedule, or
- 2. To use the kVa rating of the transformer capacity as determined by Company required to serve the Customer's connected load.

C. <u>NONRESIDENTIAL SERVICE</u>:

Service to any Customer who does not qualify for residential service in (F) below shall be designated Nonresidential.

D. <u>PARALLELING</u>:

Connection to Company's electric system, directly or indirectly, from any other source of electric power is prohibited without an express written operating agreement with Company concerning such connection.

E. RESALE OF SERVICE:

Resale of service shall be limited to the Customer's tenants using such service entirely within property described in the written agreement. Service resold to tenants shall be metered and billed to each tenant at Company's regular tariff rate schedule applicable to the type of service actually furnished the tenant. The Customer shall indemnify Company for any and all liabilities, actions or claims for injury, loss or damage to persons or property arising from the resale of service by the Customer.

(continued)

Effective: January 1, 2021

Issued: December 18, 2020 Docket No. UE-191024

Issued By PacifiCorp d/b/a Pacific Power & Light Company

By: _____ Etta Lockey Title: Vice President, Regulation



Original Sheet No. R2.3

Rule 2 GENERAL RULES AND REGULATIONS—TYPES OF SERVICE

F. RESIDENTIAL SERVICE:

Service furnished to Customers for domestic purposes in single-family dwellings, including mobile homes, apartments and flats where each dwelling unit is separately metered and billed, fraternity and sorority houses, "adult family homes", and rooming houses where not more than four rooms are used as sleeping or living quarters by persons not members of the Customer's family, but excluding dwellings where the tenancy is typically less than 30 days length, such as hotels, motels, camps, lodges and clubs. Only one rate application will be employed for each metered residential service.

Residential rates will be applicable to residential buildings served through one meter but so constructed as to provide separate living units for more than one family only when the minimum charge, basic charge and the number of kilowatt-hours in each of the rate blocks is multiplied by the maximum number of families or single-family units which could be so served.

For so long as service capacity is not increased, rewiring to multiple residential meters will not be required for multi-family structures which receive residential service through a single meter.

Residential heat pumps supplemented by electric resistance heating elements shall be designed, installed and operated such that the resistance heat is not switched on at the same time the heat pump motor starts. The Customer shall contact Company before the installation of residential space heating units.

Where the major portion of the electric service or capacity provided for dwelling is used regularly for the conduct of business, or for any nonresidential purpose, the electricity consumed in the portion so used will be separately metered and billed under the appropriate schedule. If separate circuits are not provided by the Customer, the entire premises may be classified as nonresidential and billed accordingly.

Issued: December 18, 2020 **Effective:** January 1, 2021

Docket No. UE-191024

Issued By PacifiCorp d/b/a Pacific Power & Light Company

By: _____ Etta Lockey Title: Vice President, Regulation