

# WASHINGTON

## INCENTIVES FOR MOTORS

EQUIPMENT TYPE	SIZE CATEGORY	SUB-CATEGORY	MINIMUM EFFICIENCY REQUIREMENT	CUSTOMER INCENTIVE
Variable Frequency Drives (HVAC fans and pumps)	≤ 100 horsepower	HVAC fans and pumps	See note 2	\$81/horsepower
Electronically Commutated Motor (ECM) – Retrofit only	≥ 1 and ≤ 10 hp	HVAC fans and pumps	Must meet NEMA standards	\$93/horsepower

**Notes for motor incentives:**

1. Equipment that meets or exceeds the efficiency requirements listed for the equipment category in the above table may qualify for the listed incentive.
2. Throttling or bypass devices, such as inlet vanes, bypass dampers, three-way valves or throttling valves must be removed or permanently disabled to qualify for HVAC fan or pump VFD incentives. VFDs required by or used to comply with the applicable version of the energy code are not eligible for incentives. Savings will only be realized for installations where a variable load is present.

hp = Horsepower

HVAC = Heating Ventilating and Air Conditioning

NEMA = National Electrical Manufacturers Association

VFD = Variable Frequency Drive