

Milbank Changes			10/13/2009
<b>Residential</b>			
Item	Old	New	
100 Amp Socket Only, <b>Overhead</b> surface	U7490-RL	U4517-DL-M4	The 7490 does not meet 2006 ESR dimensions (pg. 35).
100 Amp Socket Only, <b>Overhead</b> flush	UF7490-K0-MR4	UF4517-KO	The 7490 flush mount is obsolete
100 Amp Meter Socket & Circuit Breaker Combination, <b>Overhead</b> Surface	U3424-RL-100	U5852-DL	The 3424 is obsolete
100 Amp Meter Socket & Circuit Breaker Combination, <b>Overhead</b> Flush	U3424-RL-100 + KIT #3431	U5852-DL + K4086	The 3424 is obsolete
100 Amp Meter Socket & Circuit Breaker Combination, <b>Underground</b> Surface	U3564-0-100	U3584-0-100	The 3564 is obsolete
100 Amp Meter Socket & Circuit Breaker Combination, <b>Underground</b> Flush	U3564-0-100 + KIT #K3432	U3584-0-100 + K4086	The 3564 is obsolete
200 Amp Socket Only, <b>Overhead</b>	5T8K2 (kit only)	K5T (kit only)	Changed to the correct 5th terminal kit
200 Amp Socket Only, <b>Underground</b>	U3504-XL	Left other listed approved bases unchanged	U3504-XL does not meet ESR dimensions.
<b>Commercial</b>			
Entire table	U3514-XL	1X4TB series X = 1 for 100 amp, 2 for 200	U3514-XL does not meet ESR dimensions
In the 120/208 5 terminal column			5 terminal bases were changed to 4 terminal bases + 105J, 5 terminal kit
400 Amps Meter Socket & Circuit Breaker Combination		Removed entry. U3251-0-200CB	Is approved for underground only and is listed in the 400 Amp UG row.
<b>CT Equipment</b>			
Clarified type of termination on all CT equipment			
Added		K5752	
Added		K5747	
Added		CT484814-HC	This is for underground in and underground out
<b>Terminating Pull Sections</b>			
Reduced the size of the table by combining sections			
<b>Service pedestals for mobile homes &amp; temporaries</b>			
Updated the part numbers to the new part numbers	U32 series	U52 series	The U32 series is obsolete
Added meter pedestal model		MPAP	Had been removed in error

5/20/2010

Cat# U3548-X was listed as approved for both OH and UG. It is only approved for OH. Removed UG.

5/20/2010